



RICE LIBRARY PRE-DESIGN ENERGY MODELING REPORT

Sonia Barrantes, P.E.

RIPCORDER ENGINEERING



OBJECTIVE

The objective of this exercise was to use architectural schematic drawings and proposed site conditions to perform preliminary energy modeling for the future Rice Library in Kittery, Maine, with the intention of optimizing the building envelope composition for cost, energy, performance, construction methods, and to identify viable HVAC system options.

METHOD

Preliminary drawings provided by Lassel Architects (LA) were used to build an energy model using Trane Trace 700 Version 6.3.1.

Weather data used was Typical Meteorological Year 3 (TMY3) for Pease AFB/Portsmouth, NH. Summer design dry bulb temperature was 90°F, wet bulb temperature was 76°F. Winter design temperature was 2°F.

Total occupancy for the building was calculated based on the following density rates:

- Book Stacks: 100 ft² per person
- Card File: 50 ft² per person
- Conference Room: 20 ft² per person
- Indoor Play Area: ft² per person
- Maker Space: 33 ft² per person
- Multi-Purpose Assembly: 12 ft² per person
- Offices: 143 ft² per person
- Reading Area: 50 ft² per person
- All other spaces: 0 people

The occupancy schedule as a percentage of maximum occupancy was programmed as:

- Sundays & Mondays: 0%
- Tuesdays & Fridays: 10 AM – 2 PM 50%; 2 PM – 5 PM 75%
- Wednesdays & Thursdays: 12 PM – 2 PM 50%; 2 PM – 8 PM 75%
- Saturdays: 10 AM – 2 PM 100%

Outside air requirements were based on ASHRAE 90.1 ventilation standards by space use.

Outside air infiltration was modeled as 0 ACH to reflect negligible infiltration rates with a well-sealed envelope (approximately 1 ACH₅₀ or less).

The energy model was run assuming a multiple-zone variable air volume central air handler with an enthalpy recovery wheel and economizer mode. Air handler outside air pre-heat would be provided by a hot water coil, assuming natural gas providing the hot water. Air handler cooling would be provided by packaged Direct Expansion (DX) cooling. The interior building zones would be served by variable air volume boxes with electric reheat.

The Domestic Hot Water (DHW) was calculated at an average rate of 0.1 gallons per hour per occupant, varying with scheduled occupancy load. Domestic Hot Water was calculated as being provided by natural gas heating.

Electrical utility costs were based on a simplified CMP Medium General Service rate schedule for commercial users with more than 20 kW but less than 400 kW of demand. The rate structure was modeled as \$37.22 per month customer charge, \$11.72/kW demand charge, and \$0.002857/kWh consumption charge.

Gas utility costs were based on a simplified Unifit G50/T50 Low Annual Use-Low Peak Period rate schedule. The rate structure was modeled as a \$56.22 per month customer charge plus \$0.83 per therm combined energy and distribution charge.

PHASE 1

Phase 1 of energy modeling was used to compare different envelope options. In Phase 1, the roof and slab compositions were held constant while three wall assemblies were modeled each with two window assemblies. After the results of the Phase 1 energy modeling had been reviewed, Lassel Architects selected a single envelope assembly to be evaluated in Phase 2.

- Slab: 4" rigid insulation (R-16)
- Wall 1: 2 x 6 with mineral wool insulation + 2" rigid exterior insulation under face brick (R-35)
- Wall 2: 2 x 8 with mineral wool insulation + 2" rigid exterior insulation under face brick (R-42)
- Wall 3: 2 x 8 with mineral wool insulation + insulated exterior sheathing under face brick (R-30)
- Window 1: Double-pane, coated (R-2)
- Window 2: Triple-pane, Coated (R-4.5)
- Roof: 12" Structural Insulated Panel (SIP) (R-42)

PHASE 2

Phase 2 of the energy modeling was used to provide data for HVAC equipment selection and to predict yearly utility costs.

- Slab: 4" rigid insulation (R-16)
- Wall 4: 2 x 6 with dense-pack cellulose insulation + 2" exterior rigid under face brick (R-32)
- Window 3: Triple Pane, tinted 6mm glass with Low-E film, 13mm spacing, air-filled
- Roof: Vented roof with 15 inches of blown-in cellulose insulation (R-55)

RESULTS

PHASE 1

The design occupancy load was calculated to be 391 people. The total outside air required at full occupancy was 4,314 CFM.

The cooling loads, heating loads, and estimated yearly utility costs (including lighting, plug loads, and domestic hot water) for each iteration are shown below in Table 1.

Table 1 – Phase 1 Energy Model Results

Wall Type	Window Type	Cooling Load (Tons)	Heating Load (MBH)	Yearly Utility Costs
Wall 1	Window 1	38.4	159	\$9,247
Wall 2	Window 1	37.7	156	\$9,140
Wall 3	Window 1	38.2	159	\$9,253
Wall 1	Window 2	32.7	120	\$8,071
Wall 2	Window 2	32.5	118	\$8,046
Wall 3	Window 2	32.5	119	\$8,108

PHASE 2

The Phase 2 cooling and heating loads, and yearly utility costs are shown in Table 2 below. The breakdown of the cooling loads are shown in Table 3 below. Detailed Phase 2 energy model results are in Appendix 1.

Table 2 – Phase 2 Energy Model Results

Wall Type	Window Type	Cooling Load (Tons)	Heating Load (MBH)	Yearly Utility Costs
Wall 4	Window 3	32.4	150	\$8,048

Table 3 – Phase 2 Cooling Load Breakdown

Total Cooling Load	Envelope Load	Lighting Load	People Load	Ventilation Load
32.4 Tons	16%	26%	32%	26%

The Phase 2 energy model results showed System Loading (based on average monthly temperatures and occupancy rates instead of design day) showed that the cooling system only operated 96 hours per year, and only 31 hours per year were more than 24 Tons, with no hours above 30 Tons.

ANALYSIS

PHASE 1

The dominant factor in Phase 1 was the type of window. While yearly utility costs differed by no more than \$1,200, the capacity of the required cooling equipment decreased by almost 20% from Double Pane to Triple Pane windows. The difference in utility costs between the wall compositions was negligible – less than \$200 per year.

PHASE 2

The cooling load was dominated by people, and ventilation loads – accounting for more than 58% with envelope loads accounting for only 16%.

The predicted system loading leaves open the possibility of under-sizing the cooling capacity to 30 Tons or even down to 24 Tons, significantly reducing equipment size and cost. The trade-offs would be that if full occupancy ever occurred on a design summer day, full cooling would not be possible - only “comfort” cooling.

HVAC SYSTEM OPTIONS

OPTION 1 – MULTI-ZONE VARIABLE AIR VOLUME SYSTEM WITH ENERGY RECOVERY

Option 1 is a single packaged air handler located on the central portion of the roof with an integrated energy recovery enthalpy wheel, hot water coil pre-heat, and DX cooling. Condensing units would be integrated into the air handler. A single curb would serve the air handler and its energy recovery system. Basis of design: Trane Performance Climate Changer with Renewaire Energy Recovery Ventilator (ERV) and combination curb or Greenheck ERCH.

The air handler would be a Variable Air Volume (VAV) system with Variable Frequency Drives (VFDs) on all fan motors, economizer mode, and demand controlled ventilation. Approximately 8 different zones in the Library would be served by VAV boxes with electric reheat coils.

A central duct system would be run through the attic space, penetrating the ceiling to connect to the zone VAV boxes. Downstream of the VAV boxes, ductwork could be exposed or above the ceiling, depending on ceiling space and aesthetic requirements.

Pros

- Single piece of roof-top equipment with integrated condensing units, well located in the central roof would not be very visible from the exterior.
- Refrigerant is maintained exterior to the building, not triggering any ASHRAE 15 limitations.
- All heating and cooling is provided from above, with no equipment along the walls or floors.
- No condensate drainage required in the building.

Cons

- Less space temperature control in some offices and the Study Rooms/Conference Room.

OPTION 2 – CENTRAL ENERGY RECOVERY VENTILATOR WITH ZONE AIR HANDLERS

Option 2 is a central ERV located on the central portion of the roof providing ventilation air to multiple blower coil air handlers throughout the building. The blower coil air handlers would condition the ventilation air and provide additional heating and cooling required by each zone. Basis of design: Renewaire HE6XRT and Trane Blower Coil Air Handlers.

The ERV would be a Variable Air Volume (VAV) system with VFDs and demand controlled ventilation.

The ventilation air would be ducted to multiple blower coil air handlers located in the attic spaces throughout the building, serving approximately 8 different building zones. Each blower coil air handler will have DX cooling provided by an individual condensing unit, also located on the central portion of the roof and connected by refrigerant lines. Blower coil air handler re-heat would be provided by an electric coil. Downstream of the air handlers, ductwork could be exposed or above the ceiling, depending on ceiling space and aesthetic requirements.

Pros

- ERV well located in the central roof would not be very visible from the exterior.
- Refrigerant is maintained in the attic, not triggering any ASHRAE 15 limitations.
- All heating and cooling is provided from above, with no equipment along the walls or floors.

Cons

- Each air handler requires a condensing unit, so there would be multiple condensing units on the central portion of the roof.
- Multiple sets of refrigerant lines running throughout the attic.
- Blower coil air handler maintenance access would be from the attic.
- Condensate must be drained away from the blower coil air handlers.
- Less space temperature control in some offices and the Study Rooms/Conference Room.

OPTION 3 – CENTRAL ENERGY RECOVERY VENTILATOR WITH VRF SYSTEM

Option 3 is a central ERV located on the central portion of the roof providing ventilation air to the building, with space conditioning provided by a variable refrigerant flow (VRF) system (also known as “heat pump mini-splits”). Basis of design Mitsubishi PremiSys ERV with Mitsubishi VRF heat pumps.

The ERV would be a VAV system with VFDs and demand controlled ventilation. The VRF system would vary depending on space use. The Multi-Purpose Assembly and the Indoor Play Area would each have their own system that could provide low-ambient cooling. The Central Stack and Children’s Collection would be served by a shared multi-zone cold weather heat pump system, with a combination of multi-position air handlers, wall-mounted air handlers, and ceiling cassettes. The Director’s Office, Bookkeeper’s Office, Study Rooms, and Conference Room would share a multi-zone cold weather heat pump system with low-ambient cooling capability. The south-east office group (Server Room, Genealogy, Reference & Circulation, Offices and Break Room) would share a multi-zone cold weather heat pump system with low-ambient cooling capability.

The ventilation air would be ducted in the attic spaces to distribute air throughout the building. The VRF system condensers would also be located on the central portion of the roof (to the greatest extent possible depending on refrigerant line length restrictions), with refrigerant lines run to the individual air handlers. Ductwork downstream of air handlers could be exposed or above the ceiling, depending on ceiling space and aesthetic requirements

Pros

- ERV well located in the central roof would not be very visible from the exterior.
- Total space temperature control in each room.

Cons

- Multiple condensing units on the central portion of the roof.
- System design would have to consider ASHRAE 15 refrigerant volume limitations.
- Multiple sets of refrigerant lines running throughout the building.
- Condensate must be drained away from all indoor units.
- Most expensive system.

RECOMMENDATIONS

All of the occupancy numbers in this study were based on people per square foot estimates. Ripcord Engineering (RE) recommends studying projected occupancy of the new library to ensure that HVAC systems are not over- or under-sized based on actual expected occupancy numbers.

RE recommends updating the energy model based on actual proposed window performance data by pre-selecting one or more window manufacturers to evaluate. RE also recommends evaluating different window performance by building face – for example adjusting solar heat gain (SHG) or R-value to optimize building performance and cost.

RE recommends evaluating a separate HVAC system for the Multi-Purpose Assembly room during Schematic Design. Some considerations would be the effect of winter cooling in the Multi-Purpose Assembly room on re-heat requirements for other zones, cost of an additional system, and the benefits of separate control of a system that may be used frequently outside of Library business hours.

RE recommends considering installing a cooling plant smaller than the design cooling capacity, due to the unlikely concurrence of maximum occupancy with the highest outside air temperature, humidity, and solar gain. The Design Engineer will need to coordinate with the Authority Having Jurisdiction (AHJ) prior to submitting plans for permitting.

RE recommends a building envelope of:

- 4" of rigid insulation under the whole slab
- R-30+ wall with exterior insulation
- Vented roof with 15+" of blown cellulose insulation
- Triple-pane, low-e, low SHG, insulated spacer windows
- ≤ 1 ACH₅₀ airtightness

RE recommends installing a central multi-zone VAV system with energy recovery. The Server Room may require its own computer room unit.

APPENDIX 1: DETAILED PHASE 2 ENERGY MODEL RESULTS

RICE LIBRARY ENERGY MODELING

Location	KITTERY, ME
Building owner	TOWN OF KITTERY
Program user	SONIA BARRANTES
Company	RIPCORD ENGINEERING
Comments	

By	RIPCORD ENGINEERING
Dataset name	\\psf\Home\Documents\TRACE 700 Projects\16001\16001 16-03-09.trc

Calculation time	01:20 PM on 03/10/2016
TRACE® 700 version	6.3.1

Location	Portsmouth, NH	
Latitude	43.1	deg
Longitude	70.8	deg
Time Zone	5	
Elevation	0	ft
Barometric pressure	30.1	in. Hg
Air density	0.0765	lb/cu ft
Air specific heat	0.2444	Btu/lb·°F
Density-specific heat product	1.1223	Btu/h·cfm·°F
Latent heat factor	4,940.3	Btu·min/h·cu ft
Enthalpy factor	4.5914	lb·min/hr·cu ft
Summer design dry bulb	90.0	°F
Summer design wet bulb	76.0	°F
Winter design dry bulb	2.0	°F
Summer clearness number	1.000	
Winter clearness number	1.000	
Summer ground reflectance	.200	
Winter ground reflectance	.200	
Carbon Dioxide Level	400	ppm
Design simulation period	January - December	
Cooling load methodology	TETD-TA1	
Heating load methodology	UATD	




Economic Summary

Project Information


Location: KITTERY, ME
Project Name: RICE LIBRARY ENERGY MODELING
User: SONIA BARRANTES
Company: RIPCORDER ENGINEERING
Comments:

Study Life: 20 years
Cost of Capital: 10 %
Alternative 1: 16001 2x6 Dense Wall R-55 Roof 3Pane

Annual Utility Costs



Monthly Utility Costs



MONTHLY UTILITY COSTS

By RIPCORD ENGINEERING

Utility	Jan	Feb	Mar	Apr	----- Monthly Utility Costs -----				Sept	Oct	Nov	Dec	Total
					May	June	July	Aug					
Alternative 1													
Electric													
On-Pk Cons. (\$)	5	5	4	4	3	3	4	3	4	3	3	5	47
On-Pk Demand (\$)	641	634	641	625	644	573	665	695	634	474	426	619	7,273
Total (\$):	646	639	646	630	648	576	669	698	638	477	430	624	7,320
Gas													
On-Pk Cons. (\$)	61	63	60	61	60	60	61	60	61	60	60	61	728
Monthly Total (\$):	706	702	706	691	708	636	730	758	699	537	490	685	8,048

Building Area = 19,924 ft²

Utility Cost Per Area = .40 \$/ft²

MONTHLY ENERGY CONSUMPTION

By RIPCORD ENGINEERING

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Alternative: 1 16001 2x6 Dense Wall R-55 Roof 3Pane													
Electric													
On-Pk Cons. (kWh)	1,635	1,739	1,531	1,532	1,106	1,078	1,502	1,195	1,233	1,112	1,157	1,723	16,542
On-Pk Demand (kW)	52	51	52	50	52	46	54	56	51	37	33	50	56
Gas													
On-Pk Cons. (therms)	6	8	5	6	5	5	6	5	6	5	5	6	64
On-Pk Demand (therms/hr)	0	1	0	0	0	0	0	0	0	0	0	0	1

Energy Consumption

Building 3,156 Btu/(ft2-year)
 Source 8,841 Btu/(ft2-year)

Environmental Impact Analysis

CO2 No Data Available
 SO2 No Data Available
 NOX No Data Available

Floor Area 19,924 ft2

System Checksums

By RIPCORD ENGINEERING

Server Room

Computer Room Unit

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 7 / 13		Mo/Hr: Sum of		Mo/Hr: Heating Design		Mo/Hr: Heating Design		Mo/Hr: Heating Design		Cooling	Heating	
Outside Air:		OADB/WB/HR: 88 / 76 / 117		OADB: Peaks		OADB: 2		OADB: 2		OADB: 2		SADB	55.0	92.6
Space Sens. + Lat.	Plenum Sens. + Lat	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent	Space Sens	Tot Sens	Of Total (%)	Ra Plenum	76.5	65.8
Btu/h	Btu/h	Btu/h		Btu/h		Btu/h	Btu/h		Btu/h	Btu/h		Return	76.5	65.8
Envelope Loads				Envelope Loads				Envelope Loads				Fn MtrTD	0.0	0.0
Skylite Solar	0	0	0	0	0	Skylite Solar	0	0.00	Skylite Solar	0	0.00	Fn BldTD	0.0	0.0
Skylite Cond	0	0	0	0	0	Skylite Cond	0	0.00	Skylite Cond	0	0.00	Fn Frict	0.0	0.0
Roof Cond	0	16	16	1	0	Roof Cond	0	7.67	Roof Cond	-172	7.67	AIRFLOWS		
Glass Solar	631	0	631	36	631	53	Glass Solar	0	Glass Solar	0	0.00	Diffuser	53	53
Glass/Door Cond	37	0	37	2	37	3	Glass/Door Cond	-355	Glass/Door Cond	-355	15.79	Terminal	53	53
Wall Cond	76	51	127	7	76	6	Wall Cond	-385	Wall Cond	-658	29.24	Main Fan	53	53
Partition/Door	0	0	0	0	0	0	Partition/Door	0	Partition/Door	0	0.00	Sec Fan	0	0
Floor	0	0	0	0	0	0	Floor	-417	Floor	-417	18.52	Nom Vent	9	9
Adjacent Floor	0	0	0	0	0	0	Adjacent Floor	0	Adjacent Floor	0	0	AHU Vent	9	9
Infiltration	0	0	0	0	0	0	Infiltration	0	Infiltration	0	0.00	Infil	0	0
Sub Total ==>	744	67	811	46	744	62	Sub Total ==>	-1,157	Sub Total ==>	-1,602	71.22	MinStop/Rh	53	53
Internal Loads				Internal Loads				Internal Loads				Return	53	53
Lights	381	95	477	27	381	32	Lights	0	Lights	0	0.00	Exhaust	9	9
People	0	0	0	0	0	0	People	0	People	0	0.00	Rm Exh	0	0
Misc	0	0	0	0	0	0	Misc	0	Misc	0	0.00	Auxiliary	0	0
Sub Total ==>	381	95	477	27	381	32	Sub Total ==>	0	Sub Total ==>	0	0.00	Leakage Dwn	0	0
Ceiling Load				Ceiling Load				Ceiling Load				Leakage Ups	0	0
Ventilation Load	0	0	497	28	0	0	Ventilation Load	0	Ventilation Load	-673	29.93	ENGINEERING CKS		
Adj Air Trans Heat	0	0	0	0	0	0	Adj Air Trans Heat	0	Adj Air Trans Heat	0	0	% OA	16.5	16.5
Dehumid. Ov Sizing	0	0	0	0	0	0	Ov/Undr Sizing	0	Ov/Undr Sizing	0	0.00	cfm/ft²	0.36	0.36
Ov/Undr Sizing	0	0	0	0	0	0	Exhaust Heat	41	Exhaust Heat	-1.84	-1.84	cfm/ton	361.55	
Exhaust Heat	-15	-15	-1	-1	0	0	OA Preheat Diff.	0	OA Preheat Diff.	0	.000	ft²/ton	996.85	
Sup. Fan Heat	0	0	0	0	0	0	RA Preheat Diff.	0	RA Preheat Diff.	0	.000	Btu/hr-ft²	12.04	-15.30
Ret. Fan Heat	0	0	0	0	0	0	Additional Reheat	-16	Additional Reheat	.693	.693	No. People	0	
Duct Heat Pkup	0	0	0	0	0	0	Underflr Sup Ht Pkup	0	Underflr Sup Ht Pkup	0	0.00			
Underflr Sup Ht Pkup	0	0	0	0	0	0	Supply Air Leakage	0	Supply Air Leakage	0	0.00			
Supply Air Leakage	0	0	0	0	0	0	Grand Total ==>	-1,351	Grand Total ==>	-2,249	100.00			
Grand Total ==>	1,197	76	1,770	100.00	1,197	100.00	Grand Total ==>	-1,351	Grand Total ==>	-2,249	100.00			

COOLING COIL SELECTION										AREAS				HEATING COIL SELECTION						
	Total Capacity		Sens Cap. MBh	Coil Airflow cfm	Enter DB/WB/HR			Leave DB/WB/HR			Gross Total	Glass ft² (%)	Capacity MBh	Coil Airflow cfm	Ent °F	Lvg °F				
	ton	MBh			°F	°F	gr/lb	°F	°F	gr/lb										
Main Clg	0.2	1.8	1.4	53	78.4	64.3	67.1	55.0	53.2	57.3	Floor	147				Main Htg	-2.3	53	55.0	92.6
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0				Aux Htg	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	0				Preheat	0.0	0	0.0	0.0
											ExFlr	25				Reheat	-1.2	53	55.0	75.0
Total	0.2	1.8									Roof	147	0	0		Humidif	0.0	0	0.0	0.0
											Wall	343	24	7		Opt Vent	0.0	0	0.0	0.0
											Ext Door	0	0	0		Total	-2.3			

System Checksums

By RIPCORD ENGINEERING

System - 008

Variable Volume Reheat (30% Min Flow Default)

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK			TEMPERATURES			
Peaked at Time:		Mo/Hr: 6 / 20		Mo/Hr: 7 / 18		Mo/Hr: Heating Design			Cooling			Heating		
Outside Air:		OADB/WB/HR: 75 / 69 / 97		OADB: 86		OADB: 2			SADB			Ra Plenum		
Space Sens. + Lat.	Plenum Sens. + Lat	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Return <th>Ret/OA <th>Fn MtrTD <th>Fn BldTD <th>Fn Frict </th></th></th></th>	Ret/OA <th>Fn MtrTD <th>Fn BldTD <th>Fn Frict </th></th></th>	Fn MtrTD <th>Fn BldTD <th>Fn Frict </th></th>	Fn BldTD <th>Fn Frict </th>	Fn Frict	
Btu/h	Btu/h	Btu/h		Btu/h		Btu/h	Tot Sens		Btu/h					
Envelope Loads				Envelope Loads										
Skylite Solar	0	0	0	0	0	0	0	0.00						
Skylite Cond	0	0	0	0	0	0	0	0.00						
Roof Cond	0	20,310	20,310	5	0	0	-24,187	23.82						
Glass Solar	37,891	0	37,891	10	43,527	19	0	0.00						
Glass/Door Cond	2,324	0	2,324	1	7,324	3	-41,265	40.63						
Wall Cond	1,763	1,620	3,383	1	2,077	1	-8,761	18.00						
Partition/Door	0	0	0	0	0	0	0	0.00						
Floor	0	0	0	0	0	0	-13,498	13.29						
Adjacent Floor	0	0	0	0	0	0	0	0						
Infiltration	0	0	0	0	0	0	0	0.00						
Sub Total ==>	41,977	21,930	63,908	16	52,928	23	-63,524	95.74						
Internal Loads				Internal Loads										
Lights	80,724	20,181	100,904	26	80,724	35	0	-93.62						
People	123,173	0	123,173	32	76,022	33	0	-73.63						
Misc	4,483	0	4,483	1	4,483	2	0	-3.21						
Sub Total ==>	208,380	20,181	228,561	59	161,229	71	0	-170.46						
Ceiling Load	15,193	-15,193	0	0	13,843	6	-20,677	0.00						
Ventilation Load	0	0	101,307	26	0	0	0	67.59						
Adj Air Trans Heat	0	0	0	0	0	0	0	0						
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0.00						
Ov/Undr Sizing	600	600	0	0	500	0	5,024	-4.95						
Exhaust Heat	0	-11,571	-11,571	-3	0	0	-15,825	15.583						
Sup. Fan Heat	0	5,962	5,962	2	0	0	-97,992	96.493						
Ret. Fan Heat	0	0	0	0	0	0	0	.000						
Duct Heat Pkup	0	0	0	0	0	0	0	0.00						
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0.00						
Supply Air Leakage	0	0	0	0	0	0	0	0.00						
Grand Total ==>	266,150	15,347	388,767	100.00	228,500	100.00	-84,201	100.00						

AIRFLOWS		
	Cooling	Heating
Diffuser	10,498	3,321
Terminal	10,498	3,321
Main Fan	10,498	3,321
Sec Fan	0	0
Nom Vent	4,305	122
AHU Vent	4,305	122
Infil	0	0
MinStop/Rh	3,321	3,321
Return	10,323	3,269
Exhaust	4,130	3,027
Rm Exh	175	53
Auxiliary	0	0
Leakage Dwn	0	0
Leakage Ups	0	0

ENGINEERING CKS		
	Cooling	Heating
% OA	41.0	92.7
cfm/ft²	0.53	0.17
cfm/ton	324.04	
ft²/ton	610.46	
Btu/hr-ft²	19.66	-4.78
No. People	318	

COOLING COIL SELECTION										
	Total Capacity		Sens Cap.	Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR		
	ton	MBh	MBh	cfm	°F	°F	gr/lb	°F	°F	gr/lb
Main Clg	32.4	388.8	241.8	10,061	76.5	66.0	78.6	55.1	53.5	58.2
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Total	32.4	388.8								

AREAS			
	Gross Total	Glass	
		ft²	(%)
Floor	19,777		
Part	0		
Int Door	0		
ExFlr	794		
Roof	19,777	0	0
Wall	11,522	2,789	24
Ext Door	0	0	0

HEATING COIL SELECTION				
	Capacity	Coil Airflow	Ent	Lvg
	MBh	cfm	°F	°F
Main Htg	-68.7	3,321	55.1	73.5
Aux Htg	0.0	0	0.0	0.0
Preheat	-25.8	4,305	49.7	55.1
Reheat	-55.6	3,321	55.1	70.0
Humidif	0.0	0	0.0	0.0
Opt Vent	0.0	0	0.0	0.0
Total	-94.5			

Room Checksums

By RIPCORD ENGINEERING

BATHROOM - CHILD

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK			TEMPERATURES			
Peaked at Time:		Mo/Hr: 7 / 20		Mo/Hr: 7 / 23		Mo/Hr: Heating Design			Cooling			Heating		
Outside Air:		OADB/WB/HR: 81 / 73 / 111		OADB: 75		OADB: 2			SADB			Ra Plenum		
Space Sens. + Lat.	Plenum Sens. + Lat	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Return	Ret/OA	Fn MtrTD	Fn BldTD	Fn Frict	
Btu/h	Btu/h	Btu/h		Btu/h		Btu/h	Tot Sens Btu/h							
Envelope Loads				Envelope Loads										
Skylite Solar	0	0	0	0	0	0	0	0.00						
Skylite Cond	0	0	0	0	0	0	0	0.00						
Roof Cond	0	89	89	40	0	0	-110	5.49						
Glass Solar	0	0	0	0	0	0	0	0.00						
Glass/Door Cond	0	0	0	0	0	0	0	0.00						
Wall Cond	58	34	93	42	67	12	-294	14.66						
Partition/Door	0	0	0	0	0	0	0	0.00						
Floor	0	0	0	0	0	0	-170	8.48						
Adjacent Floor	0	0	0	0	0	0	0	.000						
Infiltration	0	0	0	0	0	0	0	0.00						
Sub Total ==>	58	123	181	82	67	12	-348	28.63						
Internal Loads				Internal Loads										
Lights	0	0	0	0	0	0	0	0.00						
People	0	0	0	0	0	0	0	0.00						
Misc	0	0	0	0	0	0	0	0.00						
Sub Total ==>	0	0	0	0	0	0	0	0.00						
Ceiling Load	71	-71	0	0	77	14	-94	0.00						
Ventilation Load	0	0	100	45	0	0	-572	28.55						
Adj Air Trans Heat	0	0	0	0	0	0	0	0						
Dehumid. Ov Sizing			0	0			0	0.00						
Ov/Undr Sizing	34		34	15	400	73	0	0.00						
Exhaust Heat		-98	-98	-44			-1,042	51.995						
Sup. Fan Heat			4	2			0	.000						
Ret. Fan Heat		0	0	0			0	.000						
Duct Heat Pkup		0	0	0			184	-9.17						
Underflr Sup Ht Pkup			0	0			0	.000						
Supply Air Leakage		0	0	0			0	.000						
Grand Total ==>	163	-47	221	100.00	544	100.00	-442	-2,005	100.00					

AIRFLOWS		
	Cooling	Heating
Diffuser	25	8
Terminal	25	8
Main Fan	25	8
Sec Fan	0	0
Nom Vent	25	8
AHU Vent	25	8
Infil	0	0
MinStop/Rh	8	8
Return	0	0
Exhaust	0	0
Rm Exh	25	8
Auxiliary	0	0
Leakage Dwn	0	0
Leakage Ups	0	0

ENGINEERING CKS		
	Cooling	Heating
% OA	100.0	100.0
cfm/ft²	0.28	0.08
cfm/ton	1,355.50	
ft²/ton	4,879.80	
Btu/hr-ft²	2.46	-22.27
No. People	0	

COOLING COIL SELECTION										
	Total Capacity		Sens Cap. MBh	Coil Airflow cfm	Enter DB/WB/HR			Leave DB/WB/HR		
	ton	MBh			°F	°F	gr/lb	°F	°F	gr/lb
Main Clg	0.0	0.2	0.2	8	78.4	66.5	78.1	55.1	55.1	64.3
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Total	0.0	0.2								

AREAS			
	Gross Total	Glass ft²	(%)
Floor	90		
Part	0		
Int Door	0		
ExFlr	10		
Roof	90	0	0
Wall	140	0	0
Ext Door	0	0	0

HEATING COIL SELECTION				
	Capacity MBh	Coil Airflow cfm	Ent °F	Lvg °F
Aux Htg	0.0	0	0.0	0.0
Preheat	-1.5	25	2.0	55.1
Reheat	-0.1	8	55.1	70.0
Humidif	0.0	0	0.0	0.0
Opt Vent	0.0	0	0.0	0.0
Total	-2.0			

Room Checksums

By RIPCORD ENGINEERING

BATHROOM - MENS

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK			TEMPERATURES					
Peaked at Time:		Mo/Hr: 6 / 20		Mo/Hr: 7 / 23		Mo/Hr: Heating Design			Cooling			Heating				
Outside Air:		OADB/WB/HR: 75 / 69 / 97		OADB: 75		OADB: 2			SADB			Ra Plenum				
	Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Return			Ret/OA			
	Btu/h	Btu/h	Btu/h		Btu/h		Space Sens	Tot Sens		Fn MtrTD			Fn BldTD			
							Btu/h	Btu/h		Fn Frict						
Envelope Loads				Envelope Loads												
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	0	122	122	21	0	0	0	-160	4.16							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	94	56	151	26	125	11	-285	-470	12.22							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	-272	-272	7.07							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	94	178	272	47	125	11	-557	-902	23.45							
Internal Loads				Internal Loads												
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	101	-101	0	0	113	10	-137	0	0.00							
	0	0	353	61	0	0	0	-1,145	29.75							
	0	0	0	0	0	0	0	0	0							
	0	0	0	0	0	0	0	0	0.00							
	131	0	131	23	851	78	0	0	0.00							
	0	-190	-190	-33	0	0	0	-2,085	54.187							
	0	0	9	2	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	284	-7.39								
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
Grand Total ==>	326	-113	575	100.00	1,088	100.00	-694	-3,847	100.00							

AIRFLOWS

	Cooling	Heating
Diffuser	50	15
Terminal	50	15
Main Fan	50	15
Sec Fan	0	0
Nom Vent	50	15
AHU Vent	50	15
Infil	0	0
MinStop/Rh	15	15
Return	0	0
Exhaust	0	0
Rm Exh	50	15
Auxiliary	0	0
Leakage Dwn	0	0
Leakage Ups	0	0

ENGINEERING CKS

	Cooling	Heating
% OA	100.0	100.0
cfm/ft²	0.38	0.11
cfm/ton	1,042.94	
ft²/ton	2,732.51	
Btu/hr-ft²	4.39	-29.37
No. People	0	

COOLING COIL SELECTION

	Total Capacity		Sens Cap. MBh	Coil Airflow cfm	Enter DB/WB/HR			Leave DB/WB/HR		
	ton	MBh			°F	°F	gr/lb	°F	°F	gr/lb
Main Clg	0.1	0.6	0.2	15	75.3	69.3	97.4	55.1	55.1	64.3
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Total	0.1	0.6								

AREAS

	Gross Total	Glass	
		ft²	(%)
Floor	131		
Part	0		
Int Door	0		
ExFlr	16		
Roof	131	0	0
Wall	224	0	0
Ext Door	0	0	0

HEATING COIL SELECTION

	Capacity MBh	Coil Airflow cfm	Ent Lvg	
			°F	°F
Main Htg	-0.9	15	55.1	106.7
Aux Htg	0.0	0	0.0	0.0
Preheat	-3.0	50	2.0	55.1
Reheat	-0.3	15	55.1	70.0
Humidif	0.0	0	0.0	0.0
Opt Vent	0.0	0	0.0	0.0
Total	-3.9			

Room Checksums

By RIPCORD ENGINEERING

BATHROOM - REF CIRC

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK			TEMPERATURES			
Peaked at Time:		Mo/Hr: 6 / 20		Mo/Hr: 7 / 23		Mo/Hr: Heating Design			Cooling			Heating		
Outside Air:		OADB/WB/HR: 75 / 69 / 97		OADB: 75		OADB: 2			SADB			Ra Plenum		
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Return	Ret/OA	Fn MtrTD	Fn BldTD	Fn Frict	
Btu/h	Btu/h	Btu/h		Btu/h		Btu/h	Tot Sens Btu/h							
Envelope Loads				Envelope Loads										
Skylite Solar	0	0	0	0	0	0	0	0.00						
Skylite Cond	0	0	0	0	0	0	0	0.00						
Roof Cond	0	67	67	24	0	0	-83	4.46						
Glass Solar	0	0	0	0	0	0	0	0.00						
Glass/Door Cond	0	0	0	0	0	0	0	0.00						
Wall Cond	36	21	57	20	46	8	-116	10.20						
Partition/Door	0	0	0	0	0	0	0	0.00						
Floor	0	0	0	0	0	0	-111	5.90						
Adjacent Floor	0	0	0	0	0	0	0	.000						
Infiltration	0	0	0	0	0	0	0	0.00						
Sub Total ==>	36	88	124	44	46	8	-226	20.56						
Internal Loads				Internal Loads										
Lights	0	0	0	0	0	0	0	0.00						
People	0	0	0	0	0	0	0	0.00						
Misc	0	0	0	0	0	0	0	0.00						
Sub Total ==>	0	0	0	0	0	0	0	0.00						
Ceiling Load	52	-52	0	0	59	11	-71	0.00						
Ventilation Load	0	0	176	62	0	0	0	-572	30.56					
Adj Air Trans Heat	0	0	0	0	0	0	0	0						
Dehumid. Ov Sizing			0	0				0.00						
Ov/Undr Sizing	75		75	26	440	81		0.00						
Exhaust Heat		-95	-95	-33				0.00						
Sup. Fan Heat			4	2				-1,042	55.658					
Ret. Fan Heat		0	0	0				0	.000					
Duct Heat Pkup		0	0	0				0	.000					
Underflr Sup Ht Pkup			0	0				127	-6.78					
Supply Air Leakage		0	0	0				0	.000					
Grand Total ==>	163	-59	285	100.00	544	100.00	-297	-1,873	100.00					

AIRFLOWS

	Cooling	Heating
Diffuser	25	8
Terminal	25	8
Main Fan	25	8
Sec Fan	0	0
Nom Vent	25	8
AHU Vent	25	8
Infil	0	0
MinStop/Rh	8	8
Return	0	0
Exhaust	0	0
Rm Exh	25	8
Auxiliary	0	0
Leakage Dwn	0	0
Leakage Ups	0	0

ENGINEERING CKS

	Cooling	Heating
% OA	100.0	100.0
cfm/ft²	0.37	0.11
cfm/ton	1,053.67	
ft²/ton	2,876.53	
Btu/hr-ft²	4.17	-27.44
No. People	0	

COOLING COIL SELECTION

	Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR		
	ton	MBh	cfm	°F	°F	gr/lb	°F	°F	gr/lb
Main Clg	0.0	0.3	8	75.3	69.3	97.4	55.1	55.1	64.3
Aux Clg	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Opt Vent	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Total	0.0	0.3							

AREAS

	Gross Total	Glass	
		ft²	(%)
Floor	68		
Part	0		
Int Door	0		
ExFlr	7		
Roof	68	0	0
Wall	91	0	0
Ext Door	0	0	0

HEATING COIL SELECTION

	Capacity	Coil Airflow	Ent	Lvg
	MBh	cfm	°F	°F
Main Htg	-0.4	8	55.1	100.7
Aux Htg	0.0	0	0.0	0.0
Preheat	-1.5	25	2.0	55.1
Reheat	-0.1	8	55.1	70.0
Humidif	0.0	0	0.0	0.0
Opt Vent	0.0	0	0.0	0.0
Total	-1.9			

Room Checksums

By RIPCORD ENGINEERING

BATHROOM - WOMENS

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 6 / 20		Mo/Hr: 7 / 23		Mo/Hr: Heating Design						Cooling	Heating	
Outside Air:		OADB/WB/HR: 75 / 69 / 97		OADB: 75		OADB: 2						SADB	55.6	113.0
Space Sens. + Lat.	Plenum Sens. + Lat	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Space Sens	Tot Sens	Percent Of Total	Ra Plenum	77.4	68.5
Btu/h	Btu/h	Btu/h		Btu/h		Btu/h	Btu/h		Btu/h	Btu/h		Return	77.4	68.5
Envelope Loads				Envelope Loads								Ret/OA	75.3	2.0
Skylite Solar	0	0	0	0	0	0	0	0.00	0	0	0.00	Fn MtrTD	0.1	0.0
Skylite Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	Fn BldTD	0.1	0.0
Roof Cond	0	129	129	15	0	0	-170	2.91	0	-170	13.56	Fn Frict	0.4	0.0
Glass Solar	0	0	0	0	0	0	0	0.00	0	0	0.00			
Glass/Door Cond	0	0	0	0	0	0	0	0.00	0	0	0.00			
Wall Cond	129	75	204	24	180	11	-480	-793	-480	-793	13.56			
Partition/Door	0	0	0	0	0	0	0	0.00	0	0	0.00			
Floor	0	0	0	0	0	0	-459	-459	0	-459	7.85			
Adjacent Floor	0	0	0	0	0	0	0	0.00	0	0	0.00			
Infiltration	0	0	0	0	0	0	0	0.00	0	0	0.00			
<i>Sub Total ==></i>	129	204	333	39	180	11	-939	-1,422			24.32			
Internal Loads				Internal Loads										
Lights	0	0	0	0	0	0	0	0.00	0	0	0.00			
People	0	0	0	0	0	0	0	0.00	0	0	0.00			
Misc	0	0	0	0	0	0	0	0.00	0	0	0.00			
<i>Sub Total ==></i>	0	0	0	0	0	0	0	0.00	0	0	0.00			
Ceiling Load	107	-107	0	0	120	7	-145	0	0.00	0	0.00			
Ventilation Load	0	0	529	63	0	0	0	-1,717	29.36	0	29.36			
Adj Air Trans Heat	0	0	0	0	0	0	0	0	0	0	0			
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0	0.00	0	0.00			
Ov/Undr Sizing	254	0	254	30	1,333	82	0	0	0.00	0	0.00			
Exhaust Heat	0	-286	-286	-34	0	0	0	-3,127	53.470	0	53.470			
Sup. Fan Heat	0	13	13	2	0	0	0	0	0.000	0	0.000			
Ret. Fan Heat	0	0	0	0	0	0	0	0	0.000	0	0.000			
Duct Heat Pkup	0	0	0	0	0	0	0	418	-7.15	0	-7.15			
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0	0.000	0	0.000			
Supply Air Leakage	0	0	0	0	0	0	0	0	0.000	0	0.000			
<i>Grand Total ==></i>	490	-188	844	100.00	1,632	100.00	-1,085	-5,849	100.00					

AIRFLOWS		
	Cooling	Heating
Diffuser	75	23
Terminal	75	23
Main Fan	75	23
Sec Fan	0	0
Nom Vent	75	23
AHU Vent	75	23
Infil	0	0
MinStop/Rh	23	23
Return	0	0
Exhaust	0	0
Rm Exh	75	23
Auxiliary	0	0
Leakage Dwn	0	0
Leakage Ups	0	0

ENGINEERING CKS		
	Cooling	Heating
% OA	100.0	100.0
cfm/ft²	0.54	0.16
cfm/ton	1,066.19	
ft²/ton	1,976.00	
Btu/hr-ft²	6.07	-42.08
No. People	0	

COOLING COIL SELECTION										
	Total Capacity		Sens Cap. MBh	Coil Airflow cfm	Enter DB/WB/HR			Leave DB/WB/HR		
	ton	MBh			°F	°F	gr/lb	°F	°F	gr/lb
Main Clg	0.1	0.8	0.3	23	75.3	69.3	97.4	55.1	55.1	64.3
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Total	0.1	0.8								

AREAS			
	Gross Total	Glass ft²	(%)
Floor	139		
Part	0		
Int Door	0		
ExFlr	27		
Roof	139	0	0
Wall	378	0	0
Ext Door	0	0	0

HEATING COIL SELECTION				
	Capacity MBh	Coil Airflow cfm	Ent °F	Lvg °F
Main Htg	-1.4	23	55.1	109.8
Aux Htg	0.0	0	0.0	0.0
Preheat	-4.5	75	2.0	55.1
Reheat	-0.4	23	55.1	70.0
Humidif	0.0	0	0.0	0.0
Opt Vent	0.0	0	0.0	0.0
Total	-5.9			

Room Checksums

By RIPCORD ENGINEERING

BOOK KEEPING

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK			TEMPERATURES					
Peaked at Time:		Mo/Hr: 7 / 13		Mo/Hr: 7 / 13		Mo/Hr: Heating Design			Cooling			Heating				
Outside Air:		OADB/WB/HR: 88 / 76 / 117		OADB: 88		OADB: 2			SADB			Ra Plenum				
	Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Return			Ret/OA			
	Btu/h	Btu/h	Btu/h		Btu/h		Space Sens	Tot Sens		Fn MtrTD			Fn BldTD			
							Btu/h	Btu/h		Fn Frict						
Envelope Loads				Envelope Loads												
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	0	10	10	1	0	0	0	-111	26.74							
	750	0	750	48	750	60	0	0	0.00							
	40	0	40	3	40	3	-355	-355	85.33							
	23	21	44	3	23	2	-100	-199	47.80							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	814	31	845	54	814	65	-455	-665	159.87							
Internal Loads				Internal Loads												
	197	49	246	16	197	16	0	345	-82.84							
	223	0	223	14	95	8	0	159	-38.23							
	102	0	102	6	102	8	0	155	-37.31							
	522	49	571	36	395	32	0	659	-158.38							
	38	-38	0	0	38	3	-95	0	0.00							
	0	0	134	9	0	0	0	-273	65.69							
	0	0	0	0	0	0	0	0	0							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	14	-3.45							
	0	-13	-13	-1	0	0	0	0	0.00							
	0	0	34	2	0	0	0	-221	53.036							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	70	-16.77							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
Grand Total ==>	1,373	30	1,571	100.00	1,246	100.00	Grand Total ==>	-551	-416	100.00						

AIRFLOWS

	Cooling	Heating
Diffuser	57	17
Terminal	57	17
Main Fan	57	17
Sec Fan	0	0
Nom Vent	9	0
AHU Vent	9	0
Infil	0	0
MinStop/Rh	17	17
Return	57	17
Exhaust	9	9
Rm Exh	0	0
Auxiliary	0	0
Leakage Dwn	0	0
Leakage Ups	0	0

ENGINEERING CKS

	Cooling	Heating
% OA	15.1	50.3
cfm/ft²	0.63	0.19
cfm/ton	437.15	
ft²/ton	695.14	
Btu/hr-ft²	17.26	-3.57
No. People	1	

COOLING COIL SELECTION

	Total Capacity		Sens Cap. MBh	Coil Airflow cfm	Enter DB/WB/HR			Leave DB/WB/HR		
	ton	MBh			°F	°F	gr/lb	°F	°F	gr/lb
Main Clg	0.1	1.6	1.4	57	76.8	63.7	66.8	55.1	54.6	62.4
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Total	0.1	1.6								

AREAS

	Gross Total	Glass ft²	(%)
Floor	91		
Part	0		
Int Door	0		
ExFlr	0		
Roof	91	0	0
Wall	119	24	20
Ext Door	0	0	0

HEATING COIL SELECTION

	Capacity MBh	Coil Airflow cfm	Ent °F	
			°F	°F
Main Htg	-0.3	17	55.1	70.0
Aux Htg	0.0	0	0.0	0.0
Preheat	0.0	9	51.2	55.1
Reheat	-0.3	17	55.1	70.0
Humidif	0.0	0	0.0	0.0
Opt Vent	0.0	0	0.0	0.0
Total	-0.3			

Room Checksums

By RIPCORD ENGINEERING

CENTRAL STACK

COOLING COIL PEAK					CLG SPACE PEAK					HEATING COIL PEAK					TEMPERATURES		
Peaked at Time:		Mo/Hr: 6 / 20			Mo/Hr: 7 / 19		Mo/Hr: Heating Design						Cooling	Heating			
Outside Air:		OADB/WB/HR: 75 / 69 / 97			OADB: 83		OADB: 2						SADB	55.6	92.8		
Space Sens. + Lat.	Plenum Sens. + Lat	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Space Sens	Coil Peak	Percent Of Total	Return	77.4	68.5			
Btu/h	Btu/h	Btu/h		Btu/h		Btu/h	Tot Sens		Btu/h	Btu/h		Ret/OA	76.7	51.2			
Envelope Loads					Envelope Loads										Fn MtrTD	0.1	0.0
Skylite Solar	0	0	0	0	0	Skylite Solar	0	0.00	0	0	0.00	Fn BldTD	0.1	0.0			
Skylite Cond	0	0	0	0	0	Skylite Cond	0	0.00	0	0	0.00	Fn Frict	0.4	0.0			
Roof Cond	0	9,385	6	0	0	Roof Cond	-11,129	38.66	0	0	0.00	AIRFLOWS					
Glass Solar	19,396	0	13	20,829	22	Glass Solar	0	0.00	0	0	0.00	Diffuser	4,398	1,319			
Glass/Door Cond	1,023	0	1	2,862	3	Glass/Door Cond	-18,227	63.32	-18,227	-18,227	63.32	Terminal	4,398	1,319			
Wall Cond	346	456	1	439	0	Wall Cond	-1,820	16.36	-4,708	-4,708	16.36	Main Fan	4,398	1,319			
Partition/Door	0	0	0	0	0	Partition/Door	0	0.00	0	0	0.00	Sec Fan	0	0			
Floor	0	0	0	0	0	Floor	-4,233	14.71	-4,233	-4,233	14.71	Nom Vent	1,547	0			
Adjacent Floor	0	0	0	0	0	Adjacent Floor	0	0.00	0	0	0.00	AHU Vent	1,547	0			
Infiltration	0	0	0	0	0	Infiltration	0	0.00	0	0	0.00	Infil	0	0			
Sub Total ==>	20,765	9,841	20	24,130	25	Sub Total ==>	-24,280	133.05	-38,297	-38,297	133.05	MinStop/Rh	1,319	1,319			
Internal Loads					Internal Loads										Return	4,398	1,319
Lights	42,488	10,622	34	42,488	44	Lights	0	-184.51	0	53,110	-184.51	Exhaust	1,547	1,319			
People	36,400	0	24	22,295	23	People	0	-77.46	0	22,295	-77.46	Rm Exh	0	0			
Misc	0	0	0	0	0	Misc	0	0.00	0	0	0.00	Auxiliary	0	0			
Sub Total ==>	78,888	10,622	58	64,783	68	Sub Total ==>	0	-261.96	0	75,405	-261.96	Leakage Dwn	0	0			
Ceiling Load					Ceiling Load										Leakage Ups	0	0
Ventilation Load	0	-6,991	0	6,817	7	Ventilation Load	-9,514	0.00	0	0	0.00	ENGINEERING CKS					
Adj Air Trans Heat	0	0	0	0	0	Adj Air Trans Heat	0	0.00	0	-27,801	96.58	% OA	35.2	100.0			
Dehumid. Ov Sizing	0	0	0	0	0	Dehumid. Ov Sizing	0	0.00	0	0	0.00	cfm/ft²	0.48	0.14			
Ov/Undr Sizing	0	0	0	0	0	Ov/Undr Sizing	0	0.00	0	0	0.00	cfm/ton	340.87				
Exhaust Heat	-4,209	-4,209	-3	0	0	Exhaust Heat	2,189	-7.61	0	2,189	-7.61	ft²/ton	705.29				
Sup. Fan Heat	0	2,519	2	0	0	OA Preheat Diff.	-984	3.418	0	-984	3.418	Btu/hr-ft²	17.01	-3.16			
Ret. Fan Heat	0	0	0	0	0	RA Preheat Diff.	-36,240	125.901	0	-36,240	125.901	No. People	91				
Duct Heat Pkup	0	0	0	0	0	Additional Reheat	0	0.00	0	0	0.00						
Underflr Sup Ht Pkup	0	0	0	0	0	System Plenum Heat	-3,057	10.62	0	-3,057	10.62						
Supply Air Leakage	0	0	0	0	0	Underflr Sup Ht Pkup	0	0.00	0	0	0.00						
Supply Air Leakage	0	0	0	0	0	Supply Air Leakage	0	0.00	0	0	0.00						
Grand Total ==>	106,643	9,263	100.00	95,730	100.00	Grand Total ==>	-33,794	100.00	-28,784	-28,784	100.00						

COOLING COIL SELECTION											AREAS				HEATING COIL SELECTION				
Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR			Gross Total	Glass		Capacity	Coil Airflow	Ent	Lvg				
ton	MBh	cfm	°F	°F	gr/lb	°F	°F	gr/lb		ft² (%)	MBh	cfm	°F	°F					
Main Clg	12.9	154.8	104.9	4,251	76.7	65.6	76.5	55.1	53.8	59.4	Floor	9,100	-22.1	1,319	55.1	70.0			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0	0.0	0	0.0	0.0			
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	0	-6.7	1,547	51.2	55.1			
Total	12.9	154.8									ExFlr	249	-22.1	1,319	55.1	70.0			
											Roof	9,100	0.0	0	0.0	0.0			
											Wall	3,486	1,232	35	0.0	0.0			
											Ext Door	0	0	0	0.0	0.0			
											Total	-28.8							

Room Checksums

By RIPCORD ENGINEERING

CHILD COLLECTION

COOLING COIL PEAK					CLG SPACE PEAK					HEATING COIL PEAK					TEMPERATURES			
Peaked at Time:		Mo/Hr: 6 / 20			Mo/Hr: 7 / 18		Mo/Hr: Heating Design						Cooling			Heating		
Outside Air:		OADB/WB/HR: 75 / 69 / 97			OADB: 86		OADB: 2						SADB			Ra Plenum		
	Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Space Sens	Tot Sens	Percent Of Total	Return	Ret/OA	Fn MtrTD	Fn BldTD	Fn Frict	
	Btu/h	Btu/h	Btu/h	(%)	Btu/h	(%)	Btu/h	Btu/h	(%)	Btu/h	Btu/h	(%)						
Envelope Loads					Envelope Loads										AIRFLOWS			
Skylite Solar	0	0	0	0	0	0	Skylite Solar	0	0.00	0	0	0.00	Diffuser	2,489	747			
Skylite Cond	0	0	0	0	0	0	Skylite Cond	0	0.00	0	0	0.00	Terminal	2,489	747			
Roof Cond	0	4,692	4,692	6	0	0	Roof Cond	0	35.11	-5,565	-12,296	77.58	Main Fan	2,489	747			
Glass Solar	13,554	0	13,554	17	16,019	30	Glass Solar	0	0.00	0	0	0.00	Sec Fan	0	0			
Glass/Door Cond	690	0	690	1	2,188	4	Glass/Door Cond	-12,296	77.58	-12,296	-4,382	27.64	Nom Vent	774	0			
Wall Cond	338	340	678	1	398	1	Wall Cond	-1,958	27.64	-4,382	0	0.00	AHU Vent	774	0			
Partition/Door	0	0	0	0	0	0	Partition/Door	0	0.00	0	0	0.00	Infil	0	0			
Floor	0	0	0	0	0	0	Floor	-3,468	21.88	-3,468	0	0.00	MinStop/Rh	747	747			
Adjacent Floor	0	0	0	0	0	0	Adjacent Floor	0	0.00	0	0	0.00	Return	2,489	747			
Infiltration	0	0	0	0	0	0	Infiltration	0	0.00	0	0	0.00	Exhaust	774	747			
Sub Total ==>	14,583	5,032	19,615	24	18,606	34	Sub Total ==>	-17,722	162.21	-25,710	0	0.00	Rm Exh	0	0			
Internal Loads					Internal Loads										ENGINEERING CKS			
Lights	21,244	5,311	26,555	32	21,244	39	Lights	0	-167.54	26,555	-116	-7.29	% OA	31.1	100.0			
People	18,200	0	18,200	22	11,148	21	People	0	-70.33	11,148	-12,538	79.104	cfm/ft²	0.55	0.16			
Misc	0	0	0	0	0	0	Misc	0	0.00	0	0	0.00	cfm/ton	364.99				
Sub Total ==>	39,444	5,311	44,755	55	32,391	60	Sub Total ==>	0	-237.87	37,702	0	0.00	ft²/ton	667.15				
Ceiling Load	3,495	-3,495	0	0	3,185	6	Ceiling Load	-4,757	0.00	0	0	0.00	Btu/hr-ft²	17.99	-3.48			
Ventilation Load	0	0	18,202	22	0	0	Ventilation Load	0	99.27	-15,735	0	0	Leakage Dwn	0	0			
Adj Air Trans Heat	0	0	0	0	0	0	Adj Air Trans Heat	0	0	0	0	0	Leakage Ups	0	0			
Dehumid. Ov Sizing	0	0	0	0	0	0	Ov/Undr Sizing	0	0.00	0	0	0.00						
Ov/Undr Sizing	0	0	0	0	0	0	Exhaust Heat	1,239	-7.82	0	0	0.00						
Exhaust Heat	0	-2,105	-2,105	-3	0	0	OA Preheat Diff.	-116	-7.29	0	0	0.00						
Sup. Fan Heat	0	0	1,374	2	0	0	RA Preheat Diff.	-12,538	79.104	0	0	0.00						
Ret. Fan Heat	0	0	0	0	0	0	Additional Reheat	0	0.00	-693	4.37							
Duct Heat Pkup	0	0	0	0	0	0	System Plenum Heat	0	0.00	0	0	0.00						
Underflr Sup Ht Pkup	0	0	0	0	0	0	Underflr Sup Ht Pkup	0	0.00	0	0	0.00						
Supply Air Leakage	0	0	0	0	0	0	Supply Air Leakage	0	0.00	0	0	0.00						
Grand Total ==>	57,522	4,743	81,841	100.00	54,182	100.00	Grand Total ==>	-22,479	100.00	-15,850	100.00							

COOLING COIL SELECTION										AREAS			HEATING COIL SELECTION				
	Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR			Gross Total	Glass		Capacity	Coil Airflow	Ent	Lvg	
	ton	MBh	MBh	cfm	°F	°F	gr/lb	°F	°F	gr/lb	ft²	(%)	MBh	cfm	°F	°F	
Main Clg	6.8	81.8	56.9	2,319	76.7	65.5	75.5	55.1	54.0	60.1	Floor	4,550	-12.5	747	55.1	70.0	
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0	0.0	0	0.0	0.0	
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	0	-3.3	774	51.2	55.1	
Total	6.8	81.8									ExFlr	204	-12.5	747	55.1	70.0	
											Roof	4,550	0.0	0	0.0	0.0	
											Wall	2,926	831	28	0.0	0.0	
											Ext Door	0	0	0	0.0	0.0	
											Total	-15.9					

Room Checksums

By RIPCORD ENGINEERING

CONFERENCE

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 6 / 20		Mo/Hr: 7 / 19		Mo/Hr: Heating Design						Cooling	Heating	
Outside Air:		OADB/WB/HR: 75 / 69 / 97		OADB: 83		OADB: 2						SADB	55.6	82.6
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Space Sens	Tot Sens	Percent Of Total	Ra Plenum	77.4	68.5
Btu/h	Btu/h	Btu/h		Btu/h		Btu/h	Btu/h		Btu/h	Btu/h		Return	77.4	68.5
Envelope Loads				Envelope Loads								Ret/OA	76.7	51.2
Skylite Solar	0	0	0	0	0	0	0	0.00	0	0	0.00	Fn MtrTD	0.1	0.0
Skylite Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	Fn BldTD	0.1	0.0
Roof Cond	0	261	3	0	0	0	-309	21.67	0	0	0.00	Fn Frict	0.4	0.0
Glass Solar	68	0	1	75	2	0	0	0.00	0	0	0.00	AIRFLOWS		
Glass/Door Cond	10	0	0	28	1	-178	-178	12.44	-178	-178	12.44	Diffuser	217	65
Wall Cond	23	11	0	36	1	-232	-401	28.06	-232	-401	28.06	Terminal	217	65
Partition/Door	0	0	0	0	0	0	0	0.00	0	0	0.00	Main Fan	217	65
Floor	0	0	0	0	0	-247	-247	17.26	-247	-247	17.26	Sec Fan	0	0
Adjacent Floor	0	0	0	0	0	0	0	.000	0	0	.000	Nom Vent	78	0
Infiltration	0	0	0	0	0	0	0	0.00	0	0	0.00	AHU Vent	78	0
Sub Total ==>	101	272	4	140	3	-657	-1,134	79.43	-657	-1,134	79.43	Infil	0	0
Internal Loads				Internal Loads								MinStop/Rh	65	65
Lights	850	212	1,062	12	850	18	0	-74.39	0	1,062	-74.39	Return	217	65
People	5,060	0	5,060	58	3,099	66	0	-217.06	0	3,099	-217.06	Exhaust	78	65
Misc	432	0	432	5	432	9	0	-30.24	0	432	-30.24	Rm Exh	0	0
Sub Total ==>	6,341	212	6,554	75	4,381	93	0	-321.69	0	4,593	-321.69	Auxiliary	0	0
Ceiling Load	194	-194	0	0	190	4	-265	0.00	0	0	0.00	Leakage Dwn	0	0
Ventilation Load	0	0	1,846	21	0	0	0	95.94	0	-1,370	95.94	Leakage Ups	0	0
Adj Air Trans Heat	0	0	0	0	0	0	0	0	0	0	0	ENGINEERING CKS		
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0.00	0	0	0.00	% OA	36.2	100.0
Ov/Undr Sizing	0	0	0	0	7	0	0	-7.55	0	108	-7.55	cfm/ft²	0.86	0.26
Exhaust Heat	0	-213	-213	-2	0	0	-58	4.063	0	-58	4.063	cfm/ton	299.35	
Sup. Fan Heat	0	127	127	1	0	0	-3,606	252.528	0	-3,606	252.528	ft²/ton	349.49	
Ret. Fan Heat	0	0	0	0	0	0	0	.000	0	0	.000	Btu/hr-ft²	34.34	-5.64
Duct Heat Pkup	0	0	0	0	0	0	39	-2.72	0	39	-2.72	No. People	13	
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	.000	0	0	.000			
Supply Air Leakage	0	0	0	0	0	0	0	.000	0	0	.000			
Grand Total ==>	6,637	77	8,687	100.00	4,717	100.00	-921	100.00	-921	-1,428	100.00			

COOLING COIL SELECTION										AREAS				HEATING COIL SELECTION				
	Total Capacity		Sens Cap.	Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR			Gross Total	Glass	ft² (%)	Capacity	Coil Airflow	Ent °F	Lvg °F	
	ton	MBh			MBh	cfm	°F	°F	gr/lb	°F								°F
Main Clg	0.7	8.7	4.9	215	76.7	65.7	76.5	55.1	52.3	53.8	Floor	253						
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0						
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	0						
Total	0.7	8.7									ExFlr	15						
											Roof	253	0	0				
											Wall	203	12	6				
											Ext Door	0	0	0				
											Total	-1.4						

Room Checksums

By RIPCORD ENGINEERING

CORRIDOR - ENTRY

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK			TEMPERATURES					
Peaked at Time:		Mo/Hr: 7 / 11		Mo/Hr: 7 / 11		Mo/Hr: Heating Design			Cooling			Heating				
Outside Air:		OADB/WB/HR: 82 / 74 / 114		OADB: 82		OADB: 2			SADB			Ra Plenum				
	Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Return			Ret/OA			
	Btu/h	Btu/h	Btu/h		Btu/h		Space Sens	Tot Sens		Fn MtrTD			Fn BldTD			
							Btu/h	Btu/h		Fn Frict						
Envelope Loads				Envelope Loads												
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	0	-19	-19	0	0	0	0	-636	13.36							
	5,653	0	5,653	79	5,653	87	0	0	0.00							
	123	0	123	2	123	2	-2,131	-2,131	44.77							
	0	27	27	0	0	0	0	-151	3.18							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	5,776	9	5,785	81	5,776	89	-2,131	-2,918	61.30							
Internal Loads				Internal Loads												
	562	141	703	10	562	9	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	562	141	703	10	562	9	0	0	0.00							
	171	-171	0	0	171	3	-544	0	0.00							
	0	0	409	6	0	0	0	-1,405	29.53							
	0	0	0	0	0	0	0	0	0							
	0	0	0	0	0	0	0	0	0.00							
	85	0	85	1	0	0	0	52	-1.09							
	0	-36	-36	-1	0	0	0	0	0.00							
	0	0	177	2	0	0	0	-883	18.549							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	395	-8.29							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
Grand Total ==>	6,594	-58	7,122	100.00	6,509	100.00	-2,674	-4,760	100.00							

AIRFLOWS

	Cooling	Heating
Diffuser	299	90
Terminal	299	90
Main Fan	299	90
Sec Fan	0	0
Nom Vent	31	31
AHU Vent	31	31
Infil	0	0
MinStop/Rh	90	90
Return	299	90
Exhaust	31	31
Rm Exh	0	0
Auxiliary	0	0
Leakage Dwn	0	0
Leakage Ups	0	0

ENGINEERING CKS

	Cooling	Heating
% OA	10.4	34.8
cfm/ft²	0.58	0.17
cfm/ton	503.87	
ft²/ton	876.14	
Btu/hr-ft²	13.70	-7.71
No. People	0	

COOLING COIL SELECTION

	Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR		
	ton	MBh	cfm	°F	°F	gr/lb	°F	°F	gr/lb
Main Clg	0.6	7.1	299	76.2	63.3	66.0	55.1	55.1	64.3
Aux Clg	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Opt Vent	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Total	0.6	7.1							

AREAS

	Gross Total	Glass	
		ft²	(%)
Floor	520		
Part	0		
Int Door	0		
ExFlr	0		
Roof	520	0	0
Wall	217	144	66
Ext Door	0	0	0

HEATING COIL SELECTION

	Capacity	Coil Airflow	Ent	Lvg
	MBh	cfm	°F	°F
Main Htg	-3.9	90	55.1	93.6
Aux Htg	0.0	0	0.0	0.0
Preheat	-0.1	31	51.2	55.1
Reheat	-1.5	90	55.1	70.0
Humidif	0.0	0	0.0	0.0
Opt Vent	0.0	0	0.0	0.0
Total	-4.0			

Room Checksums

By RIPCORD ENGINEERING

CORRIDOR - REAR

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 8 / 16		Mo/Hr: 10 / 15		Mo/Hr: Heating Design						Cooling	Heating	
Outside Air:		OADB/WB/HR: 86 / 76 / 116		OADB: 66		OADB: 2						SADB	55.6	101.5
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Space Sens	Tot Sens	Percent Of Total	Ra Plenum	76.7	68.5
Btu/h	Btu/h	Btu/h		Btu/h		Btu/h	Btu/h		Btu/h	Btu/h		Return	76.7	68.5
Envelope Loads				Envelope Loads								Ret/OA	77.4	54.4
Skylite Solar	0	0	0	0	0	0	0	0.00	0	0	0.00	Fn MtrTD	0.1	0.0
Skylite Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	Fn BldTD	0.1	0.0
Roof Cond	0	136	136	8	0	0	-345	34.71	0	-345	84.85	Fn Frict	0.4	0.0
Glass Solar	633	0	633	37	990	66	0	0.00	0	0	0.00			
Glass/Door Cond	48	0	48	3	-47	-3	-311	31.27	-311	-311	31.27			
Wall Cond	7	7	14	1	-6	0	-44	10.31	-44	-102	10.31			
Partition/Door	0	0	0	0	0	0	0	0.00	0	0	0.00			
Floor	0	0	0	0	0	0	-85	8.55	-85	-85	8.55			
Adjacent Floor	0	0	0	0	0	0	0	0.00	0	0	0.00			
Infiltration	0	0	0	0	0	0	0	0.00	0	0	0.00			
<i>Sub Total ==></i>	687	143	831	48	937	62	-440	84.85	-440	-843	84.85			
Internal Loads				Internal Loads								AIRFLOWS		
Lights	508	127	635	37	508	34	0	0.00	0	0	0.00	Cooling	Heating	
People	0	0	0	0	0	0	0	0.00	0	0	0.00	Diffuser	69	21
Misc	0	0	0	0	0	0	0	0.00	0	0	0.00	Terminal	69	21
<i>Sub Total ==></i>	508	127	635	37	508	34	0	0.00	0	0	0.00	Main Fan	69	21
Ceiling Load	156	-156	0	0	63	4	-295	0.00	-295	0	0.00	Sec Fan	0	0
Ventilation Load	0	0	259	15	0	0	0	35.88	0	-357	35.88	Nom Vent	17	17
Adj Air Trans Heat	0	0	0	0	0	0	0	0	0	0	0	AHU Vent	17	17
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0.00	0	0	0.00	Infil	0	0
Ov/Undr Sizing	0	0	0	0	0	0	0	0.00	0	0	0.00	MinStop/Rh	21	21
Exhaust Heat	0	-33	-33	-2	0	0	28	-2.83	0	0	0.00	Return	69	21
Sup. Fan Heat	0	37	37	2	0	0	-58	5.876	0	-58	5.876	Exhaust	17	17
Ret. Fan Heat	0	0	0	0	0	0	0	0.00	0	0	0.00	Rm Exh	0	0
Duct Heat Pkup	0	0	0	0	0	0	236	-23.78	0	236	-23.78	Auxiliary	0	0
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0.00	0	0	0.00	Leakage Dwn	0	0
Supply Air Leakage	0	0	0	0	0	0	0	0.00	0	0	0.00	Leakage Ups	0	0
Grand Total ==>	1,351	81	1,728	100.00	1,508	100.00	-735	100.00	-735	-994	100.00	ENGINEERING CKS		

COOLING COIL SELECTION										AREAS			HEATING COIL SELECTION						
	Total Capacity		Sens Cap.	Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR			Gross Total	Glass	Lvg	Capacity	Coil Airflow	Ent	Lvg		
	ton	MBh			MBh	cfm	°F	°F	gr/lb	°F								°F	gr/lb
Main Clg	0.1	1.7	1.6	62	77.4	64.3	68.6	55.1	55.1	64.3	Floor	282		Main Htg	-0.9	21	55.1	94.5	
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0		Aux Htg	0.0	0	0.0	0.0	
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	0		Preheat	-0.1	17	51.2	55.1	
Total	0.1	1.7									ExFlr	5		Reheat	-0.4	21	55.1	70.0	
											Roof	282	0	Humidif	0.0	0	0.0	0.0	
											Wall	70	21	30	Opt Vent	0.0	0	0.0	0.0
											Ext Door	0	0	0	Total	-1.0			

Room Checksums

By RIPCORD ENGINEERING

DIRECTORS OFFICE

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK			TEMPERATURES					
Peaked at Time:		Mo/Hr: 7 / 12		Mo/Hr: 7 / 13		Mo/Hr: Heating Design			Cooling			Heating				
Outside Air:		OADB/WB/HR: 86 / 75 / 116		OADB: 88		OADB: 2			SADB			Ra Plenum				
	Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Return			Ret/OA			
	Btu/h	Btu/h	Btu/h		Btu/h		Space Sens	Tot Sens		Fn MtrTD			Fn BldTD			
							Btu/h	Btu/h		Fn Frict						
Envelope Loads				Envelope Loads												
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	0	6	6	0	0	0	0	-241	6.78							
	2,379	0	2,379	59	2,251	67	0	0	0.00							
	84	0	84	2	121	4	-1,065	-1,065	29.99							
	37	41	79	2	38	1	-185	-406	11.42							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	-323	-323	9.09							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	2,501	47	2,548	64	2,410	72	-1,574	-2,035	57.28							
Internal Loads				Internal Loads												
	384	96	480	12	426	13	0	0	0.00							
	448	0	448	11	207	6	0	0	0.00							
	192	0	192	5	221	7	0	0	0.00							
	1,024	96	1,120	28	854	26	0	0	0.00							
	71	-71	0	0	81	2	-206	0	0.00							
	0	0	271	7	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	0	-24	-24	-1	0	0	0	0	0.00							
	0	90	90	2	0	0	0	-1,114	31.368							
	0	0	0	0	0	0	0	-696	19.581							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	293	-8.23							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
Grand Total ==>	3,596	48	4,005	100.00	3,345	100.00	-1,780	-3,553	100.00							

AIRFLOWS

	Cooling	Heating
Diffuser	154	46
Terminal	154	46
Main Fan	154	46
Sec Fan	0	0
Nom Vent	19	0
AHU Vent	19	0
Infil	0	0
MinStop/Rh	46	46
Return	154	46
Exhaust	19	0
Rm Exh	0	0
Auxiliary	0	0
Leakage Dwn	0	0
Leakage Ups	0	0

ENGINEERING CKS

	Cooling	Heating
% OA	12.2	0.0
cfm/ft²	0.78	0.23
cfm/ton	460.47	
ft²/ton	590.23	
Btu/hr-ft²	20.33	-12.79
No. People	1	

COOLING COIL SELECTION

	Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR			
	ton	MBh	cfm	°F	°F	gr/lb	°F	°F	gr/lb	
Main Clg	0.3	4.0	3.5	153	76.4	63.5	66.3	55.1	54.7	63.1
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Total	0.3	4.0								

AREAS

	Gross Total	Glass	
		ft²	(%)
Floor	197		
Part	0		
Int Door	0		
ExFlr	19		
Roof	197	0	0
Wall	266	72	27
Ext Door	0	0	0

HEATING COIL SELECTION

	Capacity	Coil Airflow	Ent	Lvg
	MBh	cfm	°F	°F
Main Htg	-2.4	46	55.1	102.2
Aux Htg	0.0	0	0.0	0.0
Preheat	-0.1	19	51.2	55.1
Reheat	-0.8	46	55.1	70.0
Humidif	0.0	0	0.0	0.0
Opt Vent	0.0	0	0.0	0.0
Total	-2.5			

Room Checksums

By RIPCORD ENGINEERING

GAME ROOM 1

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 6 / 20		Mo/Hr: 7 / 20		Mo/Hr: Heating Design						Cooling	Heating	
Outside Air:		OADB/WB/HR: 75 / 69 / 97		OADB: 81		OADB: 2						SADB	55.6	79.3
Space Sens. + Lat.	Plenum Sens. + Lat	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Space Sens	Tot Sens	Percent Of Total	Ra Plenum	77.4	68.5
Btu/h	Btu/h	Btu/h		Btu/h		Btu/h	Btu/h		Btu/h	Btu/h		Return	77.4	68.5
Envelope Loads				Envelope Loads								Ret/OA	76.8	52.2
Skylite Solar	0	0	0	0	0	0	0	0.00	0	0	0.00	Fn MtrTD	0.1	0.0
Skylite Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	Fn BldTD	0.1	0.0
Roof Cond	0	118	118	9	0	0	-135	58.52	0	0	0.00	Fn Frict	0.4	0.0
Glass Solar	0	0	0	0	0	0	0	0.00	0	0	0.00	AIRFLOWS		
Glass/Door Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	Diffuser	37	11
Wall Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	Terminal	37	11
Partition/Door	0	0	0	0	0	0	0	0.00	0	0	0.00	Main Fan	37	11
Floor	0	0	0	0	0	0	0	0.00	0	0	0.00	Sec Fan	0	0
Adjacent Floor	0	0	0	0	0	0	0	0.00	0	0	0.00	Nom Vent	10	0
Infiltration	0	0	0	0	0	0	0	0.00	0	0	0.00	AHU Vent	10	0
Sub Total ==>	0	118	118	9	0	0	-135	58.52	0	0	0.00	Infil	0	0
Internal Loads				Internal Loads								MinStop/Rh	11	11
Lights	333	83	417	32	333	42	0	-181.27	0	417	-181.27	Return	37	11
People	346	0	346	26	192	24	0	-83.65	0	192	-83.65	Exhaust	10	10
Misc	188	0	188	14	188	23	0	-81.65	0	188	-81.65	Rm Exh	0	0
Sub Total ==>	867	83	951	73	713	89	0	-346.57	0	797	-346.57	Auxiliary	0	0
Ceiling Load				Ceiling Load								Leakage Dwn	0	0
Ventilation Load	0	-85	0	0	87	11	-115	0.00	0	0	0.00	Leakage Ups	0	0
Adj Air Trans Heat	0	0	246	19	0	0	0	95.74	0	-220	95.74	ENGINEERING CKS		
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0.00	0	0	0.00	% OA	28.4	94.6
Ov/Undr Sizing	0	0	0	0	0	0	0	0.00	0	0	0.00	cfm/ft²	0.33	0.10
Exhaust Heat	0	-28	-28	-2	0	0	0	-7.54	0	17	-7.54	cfm/ton	337.48	
Sup. Fan Heat	0	22	22	2	0	0	-671	291.740	0	0	0.000	ft²/ton	1,009.11	
Ret. Fan Heat	0	0	0	0	0	0	0	0.000	0	0	0.000	Btu/hr-ft²	11.89	-2.09
Duct Heat Pkup	0	0	0	0	0	0	0	0.000	-19	8.12	0.000	No. People	1	
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0.000	0	0	0.000			
Supply Air Leakage	0	0	0	0	0	0	0	0.000	0	0	0.000			
Grand Total ==>	952	89	1,308	100.00	801	100.00	-115	100.00	-115	-230	100.00			

COOLING COIL SELECTION										AREAS			HEATING COIL SELECTION									
	Total Capacity		Sens Cap.	Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR			Gross Total	Glass	ft² (%)	Capacity	Coil Airflow	Ent °F	Lvg °F					
	ton	MBh			MBh	cfm	°F	°F	gr/lb	°F								°F	gr/lb	MBh	cfm	°F
Main Clg	0.1	1.3	0.9	37	76.8	65.2	73.9	55.1	53.5	58.1	Floor	110					Main Htg	-0.2	11	55.1	70.0	
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0					Aux Htg	0.0	0	0.0	0.0	
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	0					Preheat	-0.1	10	51.2	55.1	
Total	0.1	1.3									ExFlr	0					Reheat	-0.2	11	55.1	70.0	
											Roof	110	0	0			Humidif	0.0	0	0.0	0.0	
											Wall	0	0	0			Opt Vent	0.0	0	0.0	0.0	
											Ext Door	0	0	0			Total	-0.2				

Room Checksums

By RIPCORD ENGINEERING

GAME ROOM 2

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 6 / 20		Mo/Hr: 7 / 20		Mo/Hr: Heating Design						Cooling	Heating	
Outside Air:		OADB/WB/HR: 75 / 69 / 97		OADB: 81		OADB: 2						SADB	55.6	79.3
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Space Sens	Tot Sens	Percent Of Total	Ra Plenum	77.4	68.5
Btu/h	Btu/h	Btu/h		Btu/h		Btu/h	Btu/h		Btu/h	Btu/h		Return	77.4	68.5
Envelope Loads				Envelope Loads								Ret/OA	76.8	52.2
Skylite Solar	0	0	0	0	0	0	0	0.00	0	0	0.00	Fn MtrTD	0.1	0.0
Skylite Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	Fn BldTD	0.1	0.0
Roof Cond	0	135	135	9	0	0	-153	58.51	0	0	0.00	Fn Frict	0.4	0.0
Glass Solar	0	0	0	0	0	0	0	0.00	0	0	0.00	AIRFLOWS		
Glass/Door Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	Diffuser	42	13
Wall Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	Terminal	42	13
Partition/Door	0	0	0	0	0	0	0	0.00	0	0	0.00	Main Fan	42	13
Floor	0	0	0	0	0	0	0	0.00	0	0	0.00	Sec Fan	0	0
Adjacent Floor	0	0	0	0	0	0	0	0.00	0	0	0.00	Nom Vent	12	0
Infiltration	0	0	0	0	0	0	0	0.00	0	0	0.00	AHU Vent	12	0
Sub Total ==>	0	135	135	9	0	0	-153	58.51	0	0	0.00	Infil	0	0
Internal Loads				Internal Loads								MinStop/Rh	13	13
Lights	379	95	474	32	379	42	0	-181.24	0	474	-181.24	Return	42	13
People	393	0	393	26	219	24	0	-83.64	0	219	-83.64	Exhaust	12	12
Misc	213	0	213	14	213	23	0	-81.64	0	213	-81.64	Rm Exh	0	0
Sub Total ==>	986	95	1,080	73	811	89	0	-346.51	0	905	-346.51	Auxiliary	0	0
Ceiling Load				Ceiling Load								Leakage Dwn	0	0
Ventilation Load	0	-96	0	0	99	11	-131	0.00	0	0	0.00	Leakage Ups	0	0
Adj Air Trans Heat	0	0	279	19	0	0	0	95.73	0	-250	95.73	ENGINEERING CKS		
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0.00	0	0	0.00	% OA	28.4	94.6
Ov/Undr Sizing	0	0	0	0	0	0	0	0.00	0	0	0.00	cfm/ft²	0.33	0.10
Exhaust Heat	0	-32	-32	-2	0	0	0	-7.54	0	20	-7.54	cfm/ton	337.48	
Sup. Fan Heat	0	25	25	2	0	0	-762	291.699	0	0	0.00	ft²/ton	1,009.11	
Ret. Fan Heat	0	0	0	0	0	0	0	0.00	0	0	0.00	Btu/hr-ft²	11.89	-2.09
Duct Heat Pkup	0	0	0	0	0	0	0	0.00	0	-21	8.12	No. People	1	
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0.00	0	0	0.00			
Supply Air Leakage	0	0	0	0	0	0	0	0.00	0	0	0.00			
Grand Total ==>	1,082	101	1,486	100.00	910	100.00	-131	100.00	-131	-261	100.00			

COOLING COIL SELECTION										AREAS			HEATING COIL SELECTION									
	Total Capacity		Sens Cap.	Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR			Gross Total	Glass	ft² (%)	Capacity	Coil Airflow	Ent °F	Lvg °F					
	ton	MBh			MBh	cfm	°F	°F	gr/lb	°F								°F	gr/lb	MBh	cfm	°F
Main Clg	0.1	1.5	1.0	42	76.8	65.2	73.9	55.1	53.5	58.1	Floor	125					Main Htg	-0.2	13	55.1	70.0	
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0					Aux Htg	0.0	0	0.0	0.0	
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	0					Preheat	-0.1	12	51.2	55.1	
Total	0.1	1.5									ExFlr	0					Reheat	-0.2	13	55.1	70.0	
											Roof	125	0	0			Humidif	0.0	0	0.0	0.0	
											Wall	0	0	0			Opt Vent	0.0	0	0.0	0.0	
											Ext Door	0	0	0			Total	-0.3				

Room Checksums

By RIPCORD ENGINEERING

GENEAOLOGY

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 6 / 20		Mo/Hr: 7 / 20		Mo/Hr: Heating Design						Cooling	Heating	
Outside Air:		OADB/WB/HR: 75 / 69 / 97		OADB: 81		OADB: 2						SADB	55.6	79.3
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Space Sens	Tot Sens	Percent Of Total	Ra Plenum	77.4	68.5
Btu/h	Btu/h	Btu/h		Btu/h		Btu/h	Btu/h		Btu/h	Btu/h		Return	77.4	68.5
Envelope Loads				Envelope Loads								Ret/OA	76.8	52.2
Skylite Solar	0	0	0	0	0	0	0	0.00	0	0	0.00	Fn MtrTD	0.1	0.0
Skylite Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	Fn BldTD	0.1	0.0
Roof Cond	0	204	204	9	0	0	-232	58.50	0	0	0.00	Fn Frict	0.4	0.0
Glass Solar	0	0	0	0	0	0	0	0.00	0	0	0.00			
Glass/Door Cond	0	0	0	0	0	0	0	0.00	0	0	0.00			
Wall Cond	0	0	0	0	0	0	0	0.00	0	0	0.00			
Partition/Door	0	0	0	0	0	0	0	0.00	0	0	0.00			
Floor	0	0	0	0	0	0	0	0.00	0	0	0.00			
Adjacent Floor	0	0	0	0	0	0	0	0.00	0	0	0.00			
Infiltration	0	0	0	0	0	0	0	0.00	0	0	0.00			
Sub Total ==>	0	204	204	9	0	0	-232	58.50	0	-232	58.50			
Internal Loads				Internal Loads								AIRFLOWS		
Lights	576	144	720	32	576	42	0	-181.23	0	720	-181.23	Cooling	Heating	
People	598	0	598	26	332	24	0	-83.63	0	332	-83.63	Diffuser	64	19
Misc	324	0	324	14	324	23	0	-81.64	0	324	-81.64	Terminal	64	19
Sub Total ==>	1,498	144	1,642	73	1,232	89	0	-346.50	0	1,376	-346.50	Main Fan	64	19
Lighting	0	0	0	0	0	0	0	0.00	0	0	0.00	Sec Fan	0	0
OA Preheat Diff.	0	0	0	0	0	0	0	0.00	0	0	0.00	Nom Vent	18	0
Additional Reheat	0	0	0	0	0	0	0	0.00	0	0	0.00	AHU Vent	18	0
System Plenum Heat	0	0	0	0	0	0	0	0.00	0	0	0.00	Infil	0	0
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0.00	0	0	0.00	MinStop/Rh	19	19
Supply Air Leakage	0	0	0	0	0	0	0	0.00	0	0	0.00	Return	64	19
Grand Total ==>	1,644	153	2,259	100.00	1,383	100.00	-199	100.00	-199	-397	100.00	Exhaust	18	18
												ENGINEERING CKS		
												% OA	28.4	94.6
												cfm/ft²	0.33	0.10
												cfm/ton	337.48	
												ft²/ton	1,009.11	
												Btu/hr-ft²	11.89	-2.09
												No. People	1	

COOLING COIL SELECTION										AREAS			HEATING COIL SELECTION					
	Total Capacity		Sens Cap.	Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR			Gross Total	Glass	Lvg	Capacity	Coil Airflow	Ent	Lvg	
	ton	MBh			MBh	cfm	°F	°F	gr/lb	°F								°F
Main Clg	0.2	2.3	1.6	63	76.8	65.2	73.9	55.1	53.5	58.1	Floor	190		Main Htg	-0.3	19	55.1	70.0
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0		Aux Htg	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	0		Preheat	-0.1	18	51.2	55.1
											ExFlr	0		Reheat	-0.3	19	55.1	70.0
Total	0.2	2.3									Roof	190	0	Humidif	0.0	0	0.0	0.0
											Wall	0	0	Opt Vent	0.0	0	0.0	0.0
											Ext Door	0	0	Total	-0.4			

Room Checksums

By RIPCORD ENGINEERING

INDOOR PLAY AREA

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK			TEMPERATURES			
Peaked at Time:		Mo/Hr: 6 / 20		Mo/Hr: 9 / 17		Mo/Hr: Heating Design			Cooling			Heating		
Outside Air:		OADB/WB/HR: 75 / 69 / 97		OADB: 77		OADB: 2			SADB			Ra Plenum		
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Return	Ret/OA	Fn MtrTD	Fn BldTD	Fn Frict	
Btu/h	Btu/h	Btu/h		Btu/h		Space Sens	Tot Sens							
Envelope Loads				Envelope Loads										
Skylite Solar	0	0	0	0	0	Skylite Solar	0	0.00						
Skylite Cond	0	0	0	0	0	Skylite Cond	0	0.00						
Roof Cond	0	589	589	2	0	Roof Cond	0	17.54						
Glass Solar	244	0	244	1	1,223	Glass Solar	0	0.00						
Glass/Door Cond	48	0	48	0	16	Glass/Door Cond	-799	19.09						
Wall Cond	139	93	232	1	99	Wall Cond	-597	25.36						
Partition/Door	0	0	0	0	0	Partition/Door	0	0.00						
Floor	0	0	0	0	0	Floor	-680	16.25						
Adjacent Floor	0	0	0	0	0	Adjacent Floor	0	.000						
Infiltration	0	0	0	0	0	Infiltration	0	0.00						
Sub Total ==>	431	682	1,113	4	1,338	Sub Total ==>	-2,076	78.24						
Internal Loads				Internal Loads										
Lights	2,031	508	2,539	10	2,031	Lights	0	-60.68						
People	13,500	0	13,500	54	7,500	People	0	-179.23						
Misc	0	0	0	0	0	Misc	0	0.00						
Sub Total ==>	15,531	508	16,039	64	9,531	Sub Total ==>	0	-239.92						
Ceiling Load	461	-461	0	0	292	Ceiling Load	-627	0.00						
Ventilation Load	0	0	8,754	35	0	Ventilation Load	0	77.46						
Adj Air Trans Heat	0	0	0	0	0	Adj Air Trans Heat	0	0						
Dehumid. Ov Sizing	0	0	0	0	0	Ov/Undr Sizing	0	0.00						
Exhaust Heat	0	-1,012	-1,012	-4	0	Exhaust Heat	255	-6.10						
Sup. Fan Heat	0	284	284	1	0	OA Preheat Diff.	-943	22.538						
Ret. Fan Heat	0	0	0	0	0	RA Preheat Diff.	-7,174	171.449						
Duct Heat Pkup	0	0	0	0	0	Additional Reheat	154	-3.67						
Underflr Sup Ht Pkup	0	0	0	0	0	System Plenum Heat	0	.000						
Supply Air Leakage	0	0	0	0	0	Underflr Sup Ht Pkup	0	.000						
Supply Air Leakage	0	0	0	0	0	Supply Air Leakage	0	.000						
Grand Total ==>	16,423	-283	25,178	100.00	11,161	Grand Total ==>	-2,703	100.00						

AIRFLOWS

	Cooling	Heating
Diffuser	513	154
Terminal	513	154
Main Fan	513	154
Sec Fan	0	0
Nom Vent	372	0
AHU Vent	372	0
Infil	0	0
MinStop/Rh	154	154
Return	513	154
Exhaust	372	154
Rm Exh	0	0
Auxiliary	0	0
Leakage Dwn	0	0
Leakage Ups	0	0

ENGINEERING CKS

	Cooling	Heating
% OA	72.5	100.0
cfm/ft²	0.85	0.26
cfm/ton	244.39	
ft²/ton	285.96	
Btu/hr-ft²	41.96	-17.56
No. People	30	

COOLING COIL SELECTION

	Total Capacity		Sens Cap. MBh	Coil Airflow cfm	Enter DB/WB/HR			Leave DB/WB/HR		
	ton	MBh			°F	°F	gr/lb	°F	°F	gr/lb
Main Clg	2.1	25.2	10.6	479	75.8	68.0	90.0	55.1	51.1	49.0
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Total	2.1	25.2								

AREAS

	Gross Total	Glass	
		ft²	(%)
Floor	600		
Part	0		
Int Door	0		
ExFlr	40		
Roof	600	0	0
Wall	560	54	10
Ext Door	0	0	0

HEATING COIL SELECTION

	Capacity MBh	Coil Airflow cfm	Ent °F	
			°F	°F
Main Htg	-2.6	154	55.1	70.0
Aux Htg	0.0	0	0.0	0.0
Preheat	-8.0	372	36.0	55.1
Reheat	-2.6	154	55.1	70.0
Humidif	0.0	0	0.0	0.0
Opt Vent	0.0	0	0.0	0.0
Total	-10.5			

Room Checksums

By RIPCORD ENGINEERING

MAKER SPACE

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 6 / 20		Mo/Hr: 7 / 20		Mo/Hr: Heating Design						Cooling	Heating	
Outside Air:		OADB/WB/HR: 75 / 69 / 97		OADB: 81		OADB: 2						SADB	55.6	83.5
Space Sens. + Lat.	Plenum Sens. + Lat	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Space Sens	Tot Sens	Percent Of Total	Ra Plenum	77.4	68.5
Btu/h	Btu/h	Btu/h		Btu/h		Btu/h	Btu/h		Btu/h	Btu/h		Return	77.4	68.5
Envelope Loads				Envelope Loads								Ret/OA	75.8	51.2
Skylite Solar	0	0	0	0	0	0	0	0.00	0	0	0.00	Fn MtrTD	0.1	0.0
Skylite Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	Fn BldTD	0.1	0.0
Roof Cond	0	429	429	3	0	0	-509	23.21	0	-509	69.77	Fn Frict	0.4	0.0
Glass Solar	0	0	0	0	0	0	0	0.00	0	0	0.00			
Glass/Door Cond	0	0	0	0	0	0	0	0.00	0	0	0.00			
Wall Cond	95	54	149	1	137	2	-391	29.49	-391	-646	69.77			
Partition/Door	0	0	0	0	0	0	0	0.00	0	0	0.00			
Floor	0	0	0	0	0	0	-374	17.06	-374	-374	69.77			
Adjacent Floor	0	0	0	0	0	0	0	0.00	0	0	0.00			
Infiltration	0	0	0	0	0	0	0	0.00	0	0	0.00			
<i>Sub Total ==></i>	95	483	578	4	137	2	-765	69.77	-765	-1,529	69.77			
Internal Loads				Internal Loads								AIRFLOWS		
Lights	1,454	363	1,817	13	1,454	25	0	-82.91	0	1,817	-82.91	Cooling	Heating	
People	6,246	0	6,246	46	3,123	54	0	-142.49	0	3,123	-142.49	Diffuser	264	79
Misc	710	0	710	5	710	12	0	-32.39	0	710	-32.39	Terminal	264	79
<i>Sub Total ==></i>	8,410	363	8,774	64	5,287	92	0	-257.79	0	5,650	-257.79	Main Fan	264	79
Ceiling Load	320	-320	0	0	330	6	-435	0.00	-435	0	0.00	Sec Fan	0	0
Ventilation Load	0	0	4,702	34	0	0	0	76.23	0	-1,671	76.23	Nom Vent	200	0
Adj Air Trans Heat	0	0	0	0	0	0	0	0	0	0	0	AHU Vent	200	0
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0.00	0	0	0.00	Infil	0	0
Ov/Undr Sizing	0	0	0	0	0	0	0	0.00	0	0	0.00	MinStop/Rh	79	79
Exhaust Heat	0	-544	-544	-4	0	0	132	-6.00	0	132	-6.00	Return	264	79
Sup. Fan Heat	0	155	155	1	0	0	-4,327	197.402	0	-4,327	197.402	Exhaust	200	79
Ret. Fan Heat	0	0	0	0	0	0	0	0.00	0	0	0.00	Rm Exh	0	0
Duct Heat Pkup	0	0	0	0	0	0	74	-3.38	0	74	-3.38	Auxiliary	0	0
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0.00	0	0	0.00	Leakage Dwn	0	0
Supply Air Leakage	0	0	0	0	0	0	0	0.00	0	0	0.00	Leakage Ups	0	0
Grand Total ==>	8,825	-17	13,665	100.00	5,754	100.00	-1,200	100.00	-1,200	-2,192	100.00	ENGINEERING CKS		

COOLING COIL SELECTION										AREAS				HEATING COIL SELECTION					
	Total Capacity		Sens Cap.	Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR			Gross Total	Glass	ft² (%)	Capacity	Coil Airflow	Ent °F	Lvg °F		
	ton	MBh			MBh	cfm	°F	°F	gr/lb	°F								°F	gr/lb
Main Clg	1.1	13.7	5.9	262	75.8	68.0	89.6	55.1	51.1	49.1	Floor	416			Main Htg	-1.3	79	55.1	70.0
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0			Aux Htg	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	0			Preheat	-4.6	200	34.7	55.1
Total	1.1	13.7									ExFlr	22			Reheat	-1.3	79	55.1	70.0
											Roof	416	0	0	Humidif	0.0	0	0.0	0.0
											Wall	308	0	0	Opt Vent	0.0	0	0.0	0.0
											Ext Door	0	0	0	Total	-5.9			

Room Checksums

By RIPCORD ENGINEERING

MECHANICAL-JANITOR

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK			TEMPERATURES					
Peaked at Time:		Mo/Hr: 6 / 20		Mo/Hr: 7 / 23		Mo/Hr: Heating Design			Cooling			Heating				
Outside Air:		OADB/WB/HR: 75 / 69 / 97		OADB: 75		OADB: 2			SADB			Ra Plenum				
	Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Return			Ret/OA			
	Btu/h	Btu/h	Btu/h		Btu/h		Space Sens	Tot Sens		Fn MtrTD			Fn BldTD			
							Btu/h	Btu/h		Fn Frict						
Envelope Loads				Envelope Loads												
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	0	335	335	17	0	0	0	-417	30.31							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	41	17	58	3	91	7	-427	-705	51.25							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	-408	-408	29.65							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	41	352	393	20	91	7	-835	-1,530	111.21							
Internal Loads				Internal Loads												
	885	221	1,106	56	885	70	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	0	0.00							
	885	221	1,106	56	885	70	0	0	0.00							
Ceiling Load				Ceiling Load												
	262	-262	0	0	293	23	-357	0	0.00							
	0	0	481	25	0	0	0	-369	26.79							
	0	0	0	0	0	0	0	0	0							
	0	0	0	0	0	0	0	0	0.00							
	0	0	0	0	0	0	0	29	-2.11							
	0	-56	-56	-3	0	0	0	-13	.932							
	0	0	0	0	0	0	0	0	.000							
	0	0	0	0	0	0	0	0	.000							
	0	0	0	0	0	0	0	507	-36.82							
	0	0	0	0	0	0	0	0	.000							
	0	0	0	0	0	0	0	0	.000							
Grand Total ==>	1,188	256	1,957	100.00	1,269	100.00	Grand Total ==>	-1,191	-1,376	100.00						

AIRFLOWS

	Cooling	Heating
Diffuser	58	17
Terminal	58	17
Main Fan	58	17
Sec Fan	0	0
Nom Vent	20	17
AHU Vent	20	17
Infil	0	0
MinStop/Rh	17	17
Return	58	17
Exhaust	20	17
Rm Exh	0	0
Auxiliary	0	0
Leakage Dwn	0	0
Leakage Ups	0	0

ENGINEERING CKS

	Cooling	Heating
% OA	35.1	100.0
cfm/ft²	0.17	0.05
cfm/ton	357.56	
ft²/ton	2,091.07	
Btu/hr-ft²	5.74	-4.03
No. People	0	

COOLING COIL SELECTION

	Total Capacity		Sens Cap. MBh	Coil Airflow cfm	Enter DB/WB/HR			Leave DB/WB/HR		
	ton	MBh			°F	°F	gr/lb	°F	°F	gr/lb
Main Clg	0.2	2.0	1.5	55	76.6	65.7	76.8	55.1	54.1	60.5
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Total	0.2	2.0								

AREAS

	Gross Total	Glass	
		ft²	(%)
Floor	341		
Part	0		
Int Door	0		
ExFlr	24		
Roof	341	0	0
Wall	336	0	0
Ext Door	0	0	0

HEATING COIL SELECTION

	Capacity MBh	Coil Airflow cfm	Ent °F		Lvg °F
			°F	°F	
Main Htg	-1.3	17	55.1	120.7	
Aux Htg	0.0	0	0.0	0.0	0.0
Preheat	-0.1	20	51.2	55.1	
Reheat	-0.3	17	55.1	70.0	
Humidif	0.0	0	0.0	0.0	0.0
Opt Vent	0.0	0	0.0	0.0	0.0
Total	-1.4				

Room Checksums

By RIPCORD ENGINEERING

MULTI-PURPOSE ASSEMBLY

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK			TEMPERATURES			
Peaked at Time:		Mo/Hr: 6 / 20		Mo/Hr: 7 / 19		Mo/Hr: Heating Design			Cooling			Heating		
Outside Air:		OADB/WB/HR: 75 / 69 / 97		OADB: 83		OADB: 2			SADB			Ra Plenum		
	Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Return	Ret/OA	Fn MtrTD	Fn BldTD	Fn Frict
	Btu/h	Btu/h	Btu/h		Btu/h		Space Sens	Tot Sens						
Envelope Loads				Envelope Loads							AIRFLOWS			
Skylite Solar	0	0	0	0	0	0	Skylite Solar	0	0.00					
Skylite Cond	0	0	0	0	0	0	Skylite Cond	0	0.00					
Roof Cond	0	1,279	1,279	2	0	0	Roof Cond	0	-1,516	13.77				
Glass Solar	2,642	0	2,642	4	2,895	9	Glass Solar	0	0	0.00				
Glass/Door Cond	123	0	123	0	345	1	Glass/Door Cond	-2,197	-2,197	19.96				
Wall Cond	144	110	254	0	186	1	Wall Cond	-770	-1,478	13.42				
Partition/Door	0	0	0	0	0	0	Partition/Door	0	0	0.00				
Floor	0	0	0	0	0	0	Floor	-1,037	-1,037	9.42				
Adjacent Floor	0	0	0	0	0	0	Adjacent Floor	0	0	.000				
Infiltration	0	0	0	0	0	0	Infiltration	0	0	0.00				
<i>Sub Total ==></i>	2,909	1,388	4,298	7	3,427	11	<i>Sub Total ==></i>	-4,005	-6,229	56.57				
Internal Loads				Internal Loads										
Lights	4,164	1,041	5,206	8	4,164	13	Lights	0	5,206	-47.28				
People	34,100	0	34,100	55	23,250	73	People	0	23,250	-211.17				
Misc	0	0	0	0	0	0	Misc	0	0	0.00				
<i>Sub Total ==></i>	38,264	1,041	39,306	63	27,414	86	<i>Sub Total ==></i>	0	28,456	-258.45				
Ceiling Load	953	-953	0	0	929	3	Ceiling Load	-1,296	0	0.00				
Ventilation Load	0	0	19,988	32	0	0	Ventilation Load	0	-9,232	83.85				
Adj Air Trans Heat	0	0	0	0	0	0	Adj Air Trans Heat	0	0	0				
Dehumid. Ov Sizing			0	0			Ov/Undr Sizing	0	0	0.00				
Ov/Undr Sizing	0	0	0	0	20	0	Exhaust Heat		727	-6.60				
Exhaust Heat		-2,311	-2,311	-4			OA Preheat Diff.		-1,778	16.147				
Sup. Fan Heat			852	1			RA Preheat Diff.		-22,829	207.347				
Ret. Fan Heat		0	0	0			Additional Reheat		0	.000				
Duct Heat Pkup		0	0	0			System Plenum Heat		-125	1.14				
Underflr Sup Ht Pkup		0	0	0			Underflr Sup Ht Pkup		0	.000				
Supply Air Leakage		0	0	0			Supply Air Leakage		0	.000				
<i>Grand Total ==></i>	42,126	-834	62,132	100.00	31,790	100.00	<i>Grand Total ==></i>	-5,301	-11,010	100.00				

COOLING COIL SELECTION										AREAS			HEATING COIL SELECTION					
	Total Capacity		Sens Cap.	Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR			Gross Total	Glass		Capacity	Coil Airflow	Ent	Lvg	
	ton	MBh	MBh	cfm	°F	°F	gr/lb	°F	°F	gr/lb		ft² (%)	MBh	cfm	°F	°F		
Main Clg	5.2	62.1	31.6	1,437	76.2	67.0	83.9	55.1	53.1	56.6	Floor	1,240		Main Htg	-7.3	438	55.1	70.0
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0		Aux Htg	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	0		Preheat	-12.0	849	42.5	55.1
											ExFlr	61		Reheat	-7.3	438	55.1	70.0
Total	5.2	62.1									Roof	1,240	0	Humidif	0.0	0	0.0	0.0
											Wall	854	149	Opt Vent	0.0	0	0.0	0.0
											Ext Door	0	0	Total	-19.4			

Room Checksums

By RIPCORD ENGINEERING

OFFICE - CHILD

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 6 / 20		Mo/Hr: 7 / 20		Mo/Hr: Heating Design						Cooling	Heating	
Outside Air:		OADB/WB/HR: 75 / 69 / 97		OADB: 81		OADB: 2						SADB	55.6	79.3
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Space Sens	Tot Sens	Percent Of Total	Ra Plenum	77.4	68.5
Btu/h	Btu/h	Btu/h		Btu/h		Btu/h	Btu/h		Btu/h	Btu/h		Return	77.4	68.5
Envelope Loads				Envelope Loads								Ret/OA	76.8	52.2
Skylite Solar	0	0	0	0	0	0	0	0.00	0	0	0.00	Fn MtrTD	0.1	0.0
Skylite Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	Fn BldTD	0.1	0.0
Roof Cond	0	97	97	9	0	0	-110	58.51	0	0	0.00	Fn Frict	0.4	0.0
Glass Solar	0	0	0	0	0	0	0	0.00	0	0	0.00	AIRFLOWS		
Glass/Door Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	Diffuser	30	9
Wall Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	Terminal	30	9
Partition/Door	0	0	0	0	0	0	0	0.00	0	0	0.00	Main Fan	30	9
Floor	0	0	0	0	0	0	0	0.00	0	0	0.00	Sec Fan	0	0
Adjacent Floor	0	0	0	0	0	0	0	0.00	0	0	0.00	Nom Vent	9	0
Infiltration	0	0	0	0	0	0	0	0.00	0	0	0.00	AHU Vent	9	0
Sub Total ==>	0	97	97	9	0	0	-110	58.51	0	0	0.00	Infil	0	0
Internal Loads				Internal Loads								MinStop/Rh	9	9
Lights	273	68	341	32	273	42	0	-181.26	0	341	-181.26	Return	30	9
People	283	0	283	26	157	24	0	-83.64	0	157	-83.64	Exhaust	9	9
Misc	154	0	154	14	154	23	0	-81.65	0	154	-81.65	Rm Exh	0	0
Sub Total ==>	710	68	778	73	584	89	0	-346.55	0	652	-346.55	Auxiliary	0	0
Ceiling Load				Ceiling Load								Leakage Dwn	0	0
Ventilation Load	69	-69	0	0	71	11	-94	0.00	0	0	0.00	Leakage Ups	0	0
Adj Air Trans Heat	0	0	201	19	0	0	0	95.74	0	-180	95.74	ENGINEERING CKS		
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0.00	0	0	0.00	% OA	28.4	94.6
Ov/Undr Sizing	0	0	0	0	0	0	0	0.00	0	0	0.00	cfm/ft²	0.33	0.10
Exhaust Heat	0	-23	-23	-2	0	0	0	-7.54	0	14	-7.54	cfm/ton	337.49	
Sup. Fan Heat	0	18	18	2	0	0	-549	291.718	0	-549	291.718	ft²/ton	1,009.11	
Ret. Fan Heat	0	0	0	0	0	0	0	0.00	0	0	0.00	Btu/hr-ft²	11.89	-2.09
Duct Heat Pkup	0	0	0	0	0	0	-15	8.12	0	-15	8.12	No. People	1	
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0.00	0	0	0.00			
Supply Air Leakage	0	0	0	0	0	0	0	0.00	0	0	0.00			
Grand Total ==>	779	73	1,070	100.00	655	100.00	-94	100.00	-94	-188	100.00			

COOLING COIL SELECTION										AREAS			HEATING COIL SELECTION				
	Total Capacity		Sens Cap.	Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR			Gross Total	Glass	ft² (%)	Capacity	Coil Airflow	Ent °F	Lvg °F
	ton	MBh			MBh	cfm	°F	°F	gr/lb	°F							
Main Clg	0.1	1.1	0.8	30	76.8	65.2	73.9	55.1	53.5	58.1	Floor	90					
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0					
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	0					
											ExFlr	0					
Total	0.1	1.1									Roof	90	0	0			
											Wall	0	0	0			
											Ext Door	0	0	0			

Room Checksums

By RIPCORD ENGINEERING

OFFICE - MAKER

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 6 / 20		Mo/Hr: 8 / 20		Mo/Hr: Heating Design						Cooling	Heating	
Outside Air:		OADB/WB/HR: 75 / 69 / 97		OADB: 78		OADB: 2						SADB	55.6	110.7
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Space Sens	Tot Sens	Percent Of Total	Ra Plenum	77.4	68.5
Btu/h	Btu/h	Btu/h		Btu/h		Btu/h	Btu/h		Btu/h	Btu/h		Return	77.4	68.5
Envelope Loads				Envelope Loads								Ret/OA	76.9	53.5
Skylite Solar	0	0	0	0	0	0	0	0.00	0	0	0.00	Fn MtrTD	0.1	0.0
Skylite Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	Fn BldTD	0.1	0.0
Roof Cond	0	114	114	7	0	0	-150	54.50	0	-150	149.02	Fn Frict	0.4	0.0
Glass Solar	0	0	0	0	0	0	0	0.00	0	0	0.00			
Glass/Door Cond	0	0	0	0	0	0	0	0.00	0	0	0.00			
Wall Cond	55	31	86	6	86	9	-249	-411	-249	-411	149.02			
Partition/Door	0	0	0	0	0	0	0	0.00	0	0	0.00			
Floor	0	0	0	0	0	0	-238	-238	0	-238	86.22			
Adjacent Floor	0	0	0	0	0	0	0	0.00	0	0	0.00			
Infiltration	0	0	0	0	0	0	0	0.00	0	0	0.00			
<i>Sub Total ==></i>	55	145	201	13	86	9	-487	-800	-487	-800	289.74			
Internal Loads				Internal Loads										
Lights	373	93	466	30	373	38	0	-168.81	0	466	-168.81	Diffuser	45	13
People	387	0	387	25	215	22	0	-77.90	0	215	-77.90	Terminal	45	13
Misc	210	0	210	14	210	21	0	-76.04	0	210	-76.04	Main Fan	45	13
<i>Sub Total ==></i>	970	93	1,063	69	798	82	0	-322.75	0	891	-322.75	Sec Fan	0	0
Ceiling Load				Ceiling Load								Nom Vent	12	0
Ventilation Load	94	-94	0	0	93	10	-129	0	0	0	0.00	AHU Vent	12	0
Adj Air Trans Heat	0	0	275	18	0	0	0	-246	0	-246	89.16	Infil	0	0
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0	0	0	0.00	MinStop/Rh	13	13
Ov/Undr Sizing	0	0	0	0	0	0	0	0	0	0	0.00	Return	45	13
Exhaust Heat	0	-32	-32	-2	0	0	0	19	0	19	-7.02	Exhaust	12	12
Sup. Fan Heat	0	26	26	2	0	0	0	-280	0	-280	101.456	Rm Exh	0	0
Ret. Fan Heat	0	0	0	0	0	0	0	0	0	0	0.00	Auxiliary	0	0
Duct Heat Pkup	0	0	0	0	0	0	0	140	0	140	-50.59	Leakage Dwn	0	0
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0	0	0	0.00	Leakage Ups	0	0
Supply Air Leakage	0	0	0	0	0	0	0	0	0	0	0.00			
<i>Grand Total ==></i>	1,120	112	1,533	100.00	977	100.00	-616	-276	-616	-276	100.00			

AIRFLOWS		
	Cooling	Heating
Diffuser	45	13
Terminal	45	13
Main Fan	45	13
Sec Fan	0	0
Nom Vent	12	0
AHU Vent	12	0
Infil	0	0
MinStop/Rh	13	13
Return	45	13
Exhaust	12	12
Rm Exh	0	0
Auxiliary	0	0
Leakage Dwn	0	0
Leakage Ups	0	0

ENGINEERING CKS		
	Cooling	Heating
% OA	26.0	86.7
cfm/ft²	0.36	0.11
cfm/ton	351.49	
ft²/ton	963.13	
Btu/hr-ft²	12.46	-2.24
No. People	1	

COOLING COIL SELECTION										
	Total Capacity		Sens Cap.	Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR		
	ton	MBh	MBh	cfm	°F	°F	gr/lb	°F	°F	gr/lb
Main Clg	0.1	1.5	1.1	44	76.9	65.1	73.3	55.1	53.5	58.2
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0
Total	0.1	1.5								

AREAS			
	Gross Total	Glass	
		ft²	(%)
Floor	123		
Part	0		
Int Door	0		
ExFlr	14		
Roof	123	0	0
Wall	196	0	0
Ext Door	0	0	0

HEATING COIL SELECTION				
	Capacity	Coil Airflow	Ent	Lvg
	MBh	cfm	°F	°F
Main Htg	-0.2	13	55.1	70.0
Aux Htg	0.0	0	0.0	0.0
Preheat	-0.1	12	51.2	55.1
Reheat	-0.2	13	55.1	70.0
Humidif	0.0	0	0.0	0.0
Opt Vent	0.0	0	0.0	0.0
Total	-0.3			

Room Checksums

By RIPCORD ENGINEERING

OFFICE GROUP - REF CIRC

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK			TEMPERATURES					
Peaked at Time:		Mo/Hr: 7 / 12		Mo/Hr: 7 / 12		Mo/Hr: Heating Design			Cooling		Heating	SADB	55.6	108.0		
Outside Air:		OADB/WB/HR: 86 / 75 / 116		OADB: 86		OADB: 2			Ra Plenum		68.5	Return	76.1	68.5		
Space Sens. + Lat.	Plenum Sens. + Lat	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Ret/OA <th>Fn MtrTD <th>Fn BldTD <th>Fn Frict <td colspan="2"></td> </th></th></th>	Fn MtrTD <th>Fn BldTD <th>Fn Frict <td colspan="2"></td> </th></th>	Fn BldTD <th>Fn Frict <td colspan="2"></td> </th>	Fn Frict <td colspan="2"></td>				
Btu/h	Btu/h	Btu/h		Btu/h		Btu/h	Tot Sens Btu/h		76.5	0.1	0.0	0.4				
Envelope Loads				Envelope Loads							AIRFLOWS					
Skylite Solar	0	0	0	0	0	Skylite Solar	0	0.00	Cooling		Heating		Diffuser		394	118
Skylite Cond	0	0	0	0	0	Skylite Cond	0	0.00	Terminal				Main Fan		394	118
Roof Cond	0	15	15	0	0	Roof Cond	-636	6.59	Sec Fan				Nom Vent		49	0
Glass Solar	6,074	0	6,074	59	6,074	Glass Solar	0	0.00	AHU Vent				Infil		0	0
Glass/Door Cond	246	0	246	2	246	Glass/Door Cond	-3,107	32.19	MinStop/Rh				MinStop/Rh		118	118
Wall Cond	89	103	192	2	89	Wall Cond	-489	11.37	Return				Return		394	118
Partition/Door	0	0	0	0	0	Partition/Door	0	0.00	Exhaust				Exhaust		49	0
Floor	0	0	0	0	0	Floor	-893	9.25	Rm Exh				Rm Exh		0	0
Adjacent Floor	0	0	0	0	0	Adjacent Floor	0	.000	Auxiliary				Auxiliary		0	0
Infiltration	0	0	0	0	0	Infiltration	0	0.00	Leakage Dwn				Leakage Dwn		0	0
Sub Total ==>	6,409	118	6,528	63	6,409	Sub Total ==>	-4,489	59.40	Leakage Ups				Leakage Ups		0	0
Internal Loads				Internal Loads							ENGINEERING CKS					
Lights	1,013	253	1,266	12	1,013	Lights	0	0.00	% OA				% OA		12.5	0.0
People	1,182	0	1,182	11	455	People	0	0.00	cfm/ft²				cfm/ft²		0.76	0.23
Misc	507	0	507	5	507	Misc	0	0.00	cfm/ton				cfm/ton		455.75	
Sub Total ==>	2,702	253	2,955	29	1,975	Sub Total ==>	0	0.00	ft²/ton				ft²/ton		601.77	
Ceiling Load	188	-188	0	0	188	Ceiling Load	-544	0.00	Btu/hr-ft²				Btu/hr-ft²		19.94	-13.32
Ventilation Load	0	0	717	7	0	Ventilation Load	0	0.00	No. People				No. People		4	
Adj Air Trans Heat	0	0	0	0	0	Adj Air Trans Heat	0	0								
Dehumid. Ov Sizing	0	0	0	0	0	Ov/Undr Sizing	0	0.00								
Ov/Undr Sizing	0	0	0	0	0	Exhaust Heat	0	0.00								
Exhaust Heat	0	-63	-63	-1	0	OA Preheat Diff.	-2,942	30.475								
Sup. Fan Heat	0	0	233	2	0	RA Preheat Diff.	-1,783	18.467								
Ret. Fan Heat	0	0	0	0	0	Additional Reheat	0	.000								
Duct Heat Pkup	0	0	0	0	0	System Plenum Heat	805	-8.34								
Underflr Sup Ht Pkup	0	0	0	0	0	Underflr Sup Ht Pkup	0	.000								
Supply Air Leakage	0	0	0	0	0	Supply Air Leakage	0	.000								
Grand Total ==>	9,299	120	10,369	100.00	8,572	Grand Total ==>	-5,033	100.00								

COOLING COIL SELECTION										AREAS			HEATING COIL SELECTION				
	Total Capacity		Sens Cap. MBh	Coil Airflow cfm	Enter DB/WB/HR			Leave DB/WB/HR			Gross Total	Glass ft² (%)	Capacity MBh	Coil Airflow cfm	Ent °F	Lvg °F	
	ton	MBh			°F	°F	gr/lb	°F	°F	gr/lb							
Main Clg	0.9	10.4	9.1	394	76.5	63.5	66.4	55.1	54.7	63.1	Floor	520	Main Htg	-6.7	118	55.1	105.7
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0	Aux Htg	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	0	Preheat	-0.2	49	51.2	55.1
											ExFlr	53	Reheat	-2.0	118	55.1	70.0
Total	0.9	10.4									Roof	520	Humidif	0.0	0	0.0	0.0
											Wall	735	Opt Vent	0.0	0	0.0	0.0
											Ext Door	0	Total	-6.9			

Room Checksums

By RIPCORD ENGINEERING

REF OFFICE CIRC

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES					
Peaked at Time:		Mo/Hr: 6 / 20		Mo/Hr: 7 / 20		Mo/Hr: Heating Design						Cooling	Heating				
Outside Air:		OADB/WB/HR: 75 / 69 / 97		OADB: 81		OADB: 2						SADB	55.6	79.3			
Space Sens. + Lat.	Plenum Sens. + Lat	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Space Sens	Tot Sens	Percent Of Total	Ra Plenum	77.4	68.5			
Btu/h	Btu/h	Btu/h		Btu/h		Btu/h	Btu/h		Btu/h	Btu/h		Return	77.4	68.5			
Envelope Loads				Envelope Loads								Ret/OA	76.8	52.2			
Skylite Solar	0	0	0	0	0	0	0	0.00	0	0	0.00	Fn MtrTD	0.1	0.0			
Skylite Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	Fn BldTD	0.1	0.0			
Roof Cond	0	327	327	9	0	0	-372	58.50	0	0	0.00	Fn Frict	0.4	0.0			
Glass Solar	0	0	0	0	0	0	0	0.00	0	0	0.00	AIRFLOWS					
Glass/Door Cond	0	0	0	0	0	0	0	0.00	0	0	0.00				Cooling	Heating	
Wall Cond	0	0	0	0	0	0	0	0.00	0	0	0.00				Diffuser	102	31
Partition/Door	0	0	0	0	0	0	0	0.00	0	0	0.00				Terminal	102	31
Floor	0	0	0	0	0	0	0	0.00	0	0	0.00				Main Fan	102	31
Adjacent Floor	0	0	0	0	0	0	0	0.00	0	0	0.00				Sec Fan	0	0
Infiltration	0	0	0	0	0	0	0	0.00	0	0	0.00				Nom Vent	29	0
Sub Total ==>	0	327	327	9	0	0	-372	58.50	0	0	0.00				AHU Vent	29	0
Internal Loads				Internal Loads											Infil	0	0
Lights	921	230	1,152	32	921	42	0	-181.22	0	1,152	-181.22				MinStop/Rh	31	31
People	957	0	957	26	531	24	0	-83.63	0	531	-83.63	Return	102	31			
Misc	519	0	519	14	519	23	0	-81.63	0	519	-81.63	Exhaust	29	29			
Sub Total ==>	2,397	230	2,627	73	1,972	89	0	-346.48	0	2,202	-346.48	Rm Exh	0	0			
Ceiling Load				Ceiling Load								Auxiliary	0	0			
Ventilation Load	0	-234	0	0	241	11	-318	0.00	0	0	0.00	Leakage Dwn	0	0			
Adj Air Trans Heat	0	0	679	19	0	0	0	95.72	0	-608	95.72	Leakage Ups	0	0			
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0.00	0	0	0.00	ENGINEERING CKS					
Ov/Undr Sizing	0	0	0	0	0	0	0	0.00	0	0	0.00				Cooling	Heating	
Exhaust Heat	0	-79	-79	-2	0	0	48	-7.54	0	0	0.00				% OA	28.4	94.6
Sup. Fan Heat	0	60	60	2	0	0	-1,854	291.684	0	0	0.00				cfm/ft²	0.33	0.10
Ret. Fan Heat	0	0	0	0	0	0	0	0.00	0	0	0.00				cfm/ton	337.48	
Duct Heat Pkup	0	0	0	0	0	0	-52	8.12	0	0	0.00				ft²/ton	1,009.11	
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0.00	0	0	0.00				Btu/hr-ft²	11.89	-2.09
Supply Air Leakage	0	0	0	0	0	0	0	0.00	0	0	0.00				No. People	2	
Sub Total ==>	2,630	245	3,615	100.00	2,213	100.00	-318	100.00	-318	-636	100.00						

COOLING COIL SELECTION										AREAS				HEATING COIL SELECTION								
	Total Capacity		Sens Cap.	Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR			Gross Total	Glass	ft² (%)	Capacity	Coil Airflow	Ent °F	Lvg °F					
	ton	MBh			MBh	cfm	°F	°F	gr/lb	°F								°F	gr/lb	MBh	cfm	°F
Main Clg	0.3	3.6	2.5	101	76.8	65.2	73.9	55.1	53.5	58.1	Floor	304					Main Htg	-0.5	31	55.1	70.0	
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0					Aux Htg	0.0	0	0.0	0.0	
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	0					Preheat	-0.1	29	51.2	55.1	
											ExFlr	0					Reheat	-0.5	31	55.1	70.0	
Total	0.3	3.6									Roof	304	0	0			Humidif	0.0	0	0.0	0.0	
											Wall	0	0	0			Opt Vent	0.0	0	0.0	0.0	
											Ext Door	0	0	0			Total	-0.6				

Room Checksums

By RIPCORD ENGINEERING

SERVER

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 7 / 13		Mo/Hr: 7 / 13		Mo/Hr: Heating Design					Cooling	Heating		
Outside Air:		OADB/WB/HR: 88 / 76 / 117		OADB: 88		OADB: 2					SADB	55.0	92.6	
Space Sens. + Lat.	Plenum Sens. + Lat	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Space Sens	Tot Sens	Percent Of Total	Ra Plenum	76.5	65.8
Btu/h	Btu/h	Btu/h		Btu/h		Btu/h	Btu/h		Btu/h	Btu/h		Return	76.5	65.8
Envelope Loads				Envelope Loads								Ret/OA	78.4	55.3
Skylite Solar	0	0	0	0	0	0	0	0.00	0	0	0.00	Fn MtrTD	0.0	0.0
Skylite Cond	0	0	0	0	0	0	0	0.00	0	0	0.00	Fn BldTD	0.0	0.0
Roof Cond	0	16	16	1	0	0	-172	7.67	0	0	0.00	Fn Frict	0.0	0.0
Glass Solar	631	0	631	36	631	53	0	0.00	0	0	0.00			
Glass/Door Cond	37	0	37	2	37	3	-355	15.79	-355	-355	15.79			
Wall Cond	76	51	127	7	76	6	-385	29.24	-385	-658	29.24			
Partition/Door	0	0	0	0	0	0	0	0.00	0	0	0.00			
Floor	0	0	0	0	0	0	-417	18.52	0	-417	18.52			
Adjacent Floor	0	0	0	0	0	0	0	.000	0	0	.000			
Infiltration	0	0	0	0	0	0	0	0.00	0	0	0.00			
<i>Sub Total ==></i>	744	67	811	46	744	62	-1,157	71.22	-1,157	-1,602	71.22			
Internal Loads				Internal Loads								AIRFLOWS		
Lights	381	95	477	27	381	32	0	0.00	0	0	0.00	Cooling	Heating	
People	0	0	0	0	0	0	0	0.00	0	0	0.00	Diffuser	53	53
Misc	0	0	0	0	0	0	0	0.00	0	0	0.00	Terminal	53	53
<i>Sub Total ==></i>	381	95	477	27	381	32	0	0.00	0	0	0.00	Main Fan	53	53
Ceiling Load				Ceiling Load								Sec Fan	0	0
Ventilation Load	0	0	497	28	0	0	-195	0.00	0	0	0.00	Nom Vent	9	9
Adj Air Trans Heat	0	0	0	0	0	0	0	29.93	0	-673	29.93	AHU Vent	9	9
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0.00	0	0	0.00	Infil	0	0
Ov/Undr Sizing	0	0	0	0	0	0	0	0.00	0	0	0.00	MinStop/Rh	53	53
Exhaust Heat	0	-15	-15	-1	0	0	0	-1.84	0	41	-1.84	Return	53	53
Sup. Fan Heat	0	0	0	0	0	0	0	.000	0	0	.000	Exhaust	9	9
Ret. Fan Heat	0	0	0	0	0	0	0	.000	0	0	.000	Rm Exh	0	0
Duct Heat Pkup	0	0	0	0	0	0	0	0.00	0	0	0.00	Auxiliary	0	0
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0.00	0	0	0.00	Leakage Dwn	0	0
Supply Air Leakage	0	0	0	0	0	0	0	.000	0	0	.000	Leakage Ups	0	0
<i>Grand Total ==></i>	1,197	76	1,770	100.00	1,197	100.00	-1,351	100.00	-1,351	-2,249	100.00	ENGINEERING CKS		

COOLING COIL SELECTION										AREAS			HEATING COIL SELECTION								
	Total Capacity		Sens Cap.	Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR			Gross Total	Glass	ft² (%)	Capacity	Coil Airflow	Ent °F	Lvg °F				
	ton	MBh			MBh	cfm	°F	°F	gr/lb	°F								°F	gr/lb	MBh	cfm
Main Clg	0.2	1.8	1.4	53	78.4	64.3	67.1	55.0	53.2	57.3	Floor	147					Main Htg	-2.3	53	55.0	92.6
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0					Aux Htg	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	0					Preheat	0.0	0	0.0	0.0
<i>Total</i>	0.2	1.8									ExFlr	25					Reheat	-1.2	53	55.0	75.0
											Roof	147	0	0			Humidif	0.0	0	0.0	0.0
											Wall	343	24	7			Opt Vent	0.0	0	0.0	0.0
											Ext Door	0	0	0			<i>Total</i>	-2.3			

Room Checksums

By RIPCORD ENGINEERING

STORAGE

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 6 / 20		Mo/Hr: 7 / 20		Mo/Hr: Heating Design						Cooling	Heating	
Outside Air:		OADB/WB/HR: 75 / 69 / 97		OADB: 81		OADB: 2						SADB	55.6	186.0
Space Sens. + Lat.	Plenum Sens. + Lat	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Space Sens	Tot Sens	Percent Of Total	Ra Plenum	77.4	68.5
Btu/h	Btu/h	Btu/h		Btu/h		Btu/h	Btu/h		Btu/h	Btu/h		Return	77.4	68.5
Envelope Loads				Envelope Loads								Ret/OA	75.5	51.2
Skylite Solar	0	0	0	0	0	Skylite Solar	0	0.00				Fn MtrTD	0.1	0.0
Skylite Cond	0	0	0	0	0	Skylite Cond	0	0.00				Fn BldTD	0.1	0.0
Roof Cond	0	83	83	15	0	Roof Cond	0	19.74				Fn Frict	0.4	0.0
Glass Solar	0	0	0	0	0	Glass Solar	0	0.00				AIRFLOWS		
Glass/Door Cond	0	0	0	0	0	Glass/Door Cond	0	0.00				Diffuser	13	4
Wall Cond	29	15	44	8	44	16	Wall Cond	61.29	-205	-338		Terminal	13	4
Partition/Door	0	0	0	0	0	0	Partition/Door	0.00	0	0		Main Fan	13	4
Floor	0	0	0	0	0	0	Floor	35.46	-196	-196		Sec Fan	0	0
Adjacent Floor	0	0	0	0	0	0	Adjacent Floor	0.00	0	0		Nom Vent	11	4
Infiltration	0	0	0	0	0	0	Infiltration	0.00	0	0		AHU Vent	11	4
Sub Total ==>	29	98	127	23	44	16	Sub Total ==>	116.50	-400	-642		Infil	0	0
Internal Loads				Internal Loads								MinStop/Rh	4	4
Lights	160	40	200	36	160	58	Lights	0.00	0	0		Return	13	4
People	0	0	0	0	0	0	People	0.00	0	0		Exhaust	11	4
Misc	0	0	0	0	0	0	Misc	0.00	0	0		Rm Exh	0	0
Sub Total ==>	160	40	200	36	160	58	Sub Total ==>	0.00	0	0		Auxiliary	0	0
Ceiling Load				Ceiling Load								Leakage Dwn	0	0
Ventilation Load	0	-68	0	0	71	26	Ventilation Load	0.00	-93	0		Leakage Ups	0	0
Adj Air Trans Heat	0	0	251	45	0	0	Adj Air Trans Heat	14.47	0	-80		ENGINEERING CKS		
Dehumid. Ov Sizing	0	0	0	0	0	0	Ov/Undr Sizing	0.00	0	0		% OA	84.7	100.0
Ov/Undr Sizing	0	0	0	0	0	0	Exhaust Heat	-1.14	6	-30		cfm/ft²	0.14	0.04
Exhaust Heat	0	-29	-29	-5	0	0	OA Preheat Diff.	5.408	0	0		cfm/ton	271.92	
Sup. Fan Heat	0	7	7	1	0	0	RA Preheat Diff.	0.000	0	0		ft²/ton	1,918.19	
Ret. Fan Heat	0	0	0	0	0	0	Additional Reheat	0.000	0	0		Btu/hr-ft²	6.26	-8.97
Duct Heat Pkup	0	0	0	0	0	0	System Plenum Heat	-35.24	194	-35.24		No. People	0	
Underflr Sup Ht Pkup	0	0	0	0	0	0	Underflr Sup Ht Pkup	0.000	0	0				
Supply Air Leakage	0	0	0	0	0	0	Supply Air Leakage	0.000	0	0				
Grand Total ==>	258	40	557	100.00	275	100.00	Grand Total ==>	100.00	-493	-551				

COOLING COIL SELECTION										AREAS				HEATING COIL SELECTION				
	Total Capacity		Sens Cap.	Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR			Gross Total	Glass	ft² (%)	Capacity	Coil Airflow	Ent	Lvg	
	ton	MBh			MBh	cfm	°F	°F	gr/lb	°F								°F
Main Clg	0.1	0.6	0.3	12	75.5	68.7	94.1	55.1	54.1	60.6	Floor	89						
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0						
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	0						
											ExFlr	12						
Total	0.1	0.6									Roof	89	0	0				
											Wall	161	0	0				
											Ext Door	0	0	0				

Room Checksums

By RIPCORD ENGINEERING

STUDY ROOM 2

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK			TEMPERATURES					
Peaked at Time:		Mo/Hr: 6 / 20		Mo/Hr: 7 / 17		Mo/Hr: Heating Design			Cooling	Heating						
Outside Air:		OADB/WB/HR: 75 / 69 / 97		OADB: 88		OADB: 2			SADB	55.6	89.0					
Space Sens. + Lat.	Plenum Sens. + Lat	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total	Return	77.4	68.5					
Btu/h	Btu/h	Btu/h		Btu/h		Space Sens	Tot Sens		Ret/OA	76.7	51.2					
Envelope Loads				Envelope Loads							AIRFLOWS					
Internal Loads				Internal Loads							Cooling			Heating		
Skylite Solar	0	0	0	0	0	0	0	0.00	Diffuser	93	28	Terminal	93	28		
Skylite Cond	0	0	0	0	0	0	0	0.00	Main Fan	93	28	Sec Fan	0	0		
Roof Cond	0	102	102	3	0	0	-127	20.99	Nom Vent	32	0	AHU Vent	32	0		
Glass Solar	57	0	57	2	94	5	0	0.00	Infil	0	0	MinStop/Rh	28	28		
Glass/Door Cond	12	0	12	0	37	2	-200	32.96	Return	93	28	Exhaust	32	28		
Wall Cond	20	12	32	1	23	1	-131	38.92	Rm Exh	0	0	Auxiliary	0	0		
Partition/Door	0	0	0	0	0	0	0	0.00	Leakage Dwn	0	0	Leakage Ups	0	0		
Floor	0	0	0	0	0	0	-153	25.25	ENGINEERING CKS							
Adjacent Floor	0	0	0	0	0	0	0	.000	% OA	34.7	100.0					
Infiltration	0	0	0	0	0	0	0	0.00	cfm/ft²	0.89	0.27					
Sub Total ==>	89	114	203	6	153	8	-484	-311.56	cfm/ton	307.76						
Lights	349	87	437	12	349	17	0	-72.04	ft²/ton	344.62						
People	2,080	0	2,080	57	1,274	63	0	-210.23	Btu/hr-ft²	34.82	-5.83					
Misc	177	0	177	5	177	9	0	-29.29	No. People	5						
Sub Total ==>	2,607	87	2,694	74	1,801	89	0	-311.56								
Ceiling Load	80	-80	0	0	67	3	-109	0.00								
Ventilation Load	0	0	759	21	0	0	0	-587	96.88							
Adj Air Trans Heat	0	0	0	0	0	0	0	0	0							
Dehumid. Ov Sizing			0	0			0	0	0.00							
Ov/Undr Sizing	0		0	0	0	0	46	-7.63								
Exhaust Heat		-88	-88	-2			-19	3.122								
Sup. Fan Heat			54	1			-1,268	209.208								
Ret. Fan Heat		0	0	0			0	.000								
Duct Heat Pkup		0	0	0			49	-8.14								
Underflr Sup Ht Pkup		0	0	0			0	.000								
Supply Air Leakage		0	0	0			0	.000								
Grand Total ==>	2,775	34	3,621	100.00	2,022	100.00	-593	-606	100.00							

COOLING COIL SELECTION										AREAS			HEATING COIL SELECTION			
Total Capacity	Sens Cap.		Coil Airflow	Enter DB/WB/HR			Leave DB/WB/HR			Gross Total	Glass	Capacity		Coil Airflow	Ent	Lvg
ton	MBh		cfm	°F	°F	gr/lb	°F	°F	gr/lb		ft² (%)	MBh	cfm	°F	°F	
Main Clg	0.3	3.6	90	76.7	65.6	76.2	55.1	52.4	54.1	Floor	104	-0.5	28	55.1	70.0	
Aux Clg	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0	0.0	0	0.0	0.0	
Opt Vent	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	0	-0.1	32	51.2	55.1	
Total	0.3	3.6	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	9	-0.5	28	55.1	70.0	
										Roof	104	0.0	0	0.0	0.0	
										Wall	126	0.0	0	0.0	0.0	
										Ext Door	0	0.0	0	0.0	0.0	
										Total	-0.6					

SYSTEM LOAD PROFILES

By RIPCORDER ENGINEERING

**16001 2x6 Dense Wall R-55 Roof 3Pane
Server Room**

Percent Design Load	---- Cooling Load ----			---- Heating Load ----			---- Cooling Airflow ----			---- Heating Airflow----		
	Cap. (Tons)	Hours (%)	Hours	Cap. (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	0.0	2	64	-112.5	2	71	2.7	0	0	0.0	0	0
5 - 10	0.0	7	200	-224.9	5	159	5.3	0	0	0.0	0	0
10 - 15	0.0	8	248	-337.3	11	317	8.0	0	0	0.0	0	0
15 - 20	0.0	14	403	-449.8	23	697	10.7	0	0	0.0	0	0
20 - 25	0.0	18	523	-562.2	38	1,135	13.3	0	0	0.0	0	0
25 - 30	0.0	17	501	-674.7	17	519	16.0	0	0	0.0	0	0
30 - 35	0.1	7	215	-787.1	3	84	18.7	0	0	0.0	0	0
35 - 40	0.1	10	294	-899.6	0	0	21.3	0	0	0.0	0	0
40 - 45	0.1	9	257	-1,012.0	0	0	24.0	0	0	0.0	0	0
45 - 50	0.1	4	119	-1,124.5	0	0	26.7	0	0	0.0	0	0
50 - 55	0.1	2	67	-1,236.9	0	0	29.3	0	0	0.0	0	0
55 - 60	0.1	3	93	-1,349.3	0	0	32.0	0	0	0.0	0	0
60 - 65	0.1	0	0	-1,461.8	0	0	34.7	0	0	0.0	0	0
65 - 70	0.1	0	0	-1,574.2	0	0	37.3	0	0	0.0	0	0
70 - 75	0.1	0	0	-1,686.7	0	0	40.0	0	0	0.0	0	0
75 - 80	0.1	0	0	-1,799.1	0	0	42.7	0	0	0.0	0	0
80 - 85	0.1	0	0	-1,911.6	0	0	45.3	0	0	0.0	0	0
85 - 90	0.1	0	0	-2,024.0	0	0	48.0	0	0	0.0	0	0
90 - 95	0.1	0	0	-2,136.5	0	0	50.7	0	0	0.0	0	0
95 - 100	0.2	0	0	-2,248.9	0	0	53.3	100	8,760	0.0	0	0
Hours Off	0.0	0	5,776	.0	0	5,778	0.0	0	0	0.0	0	8,760

SYSTEM LOAD PROFILES

By RIPCORDER ENGINEERING

**16001 2x6 Dense Wall R-55 Roof 3Pane
System - 008**

Percent Design Load	---- Cooling Load ----			---- Heating Load ----			---- Cooling Airflow ----			---- Heating Airflow----		
	Cap. (Tons)	Hours (%)	Hours	Cap. (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	1.6	8	8	-4,725.6	89	1,554	524.9	98	8,552	0.0	0	0
5 - 10	3.2	17	16	-9,451.2	5	81	1,049.8	0	0	0.0	0	0
10 - 15	4.9	0	0	-14,176.8	0	0	1,574.7	0	0	0.0	0	0
15 - 20	6.5	0	0	-18,902.4	1	16	2,099.6	0	0	0.0	0	0
20 - 25	8.1	0	0	-23,628.0	0	0	2,624.5	0	0	0.0	0	0
25 - 30	9.7	0	0	-28,353.7	0	0	3,149.4	0	0	0.0	0	0
30 - 35	11.4	0	0	-33,079.3	0	5	3,674.3	1	124	0.0	0	0
35 - 40	13.0	10	10	-37,804.9	0	0	4,199.1	0	12	0.0	0	0
40 - 45	14.6	10	10	-42,530.5	0	0	4,724.0	0	0	0.0	0	0
45 - 50	16.2	0	0	-47,256.1	1	10	5,248.9	0	0	0.0	0	0
50 - 55	17.8	4	4	-51,981.7	0	0	5,773.8	0	0	0.0	0	0
55 - 60	19.5	13	12	-56,707.3	2	37	6,298.7	0	0	0.0	0	0
60 - 65	21.1	0	0	-61,432.9	0	4	6,823.6	0	0	0.0	0	0
65 - 70	22.7	0	0	-66,158.5	0	4	7,348.5	0	0	0.0	0	0
70 - 75	24.3	0	0	-70,884.1	1	12	7,873.4	0	4	0.0	0	0
75 - 80	25.9	0	0	-75,609.7	0	4	8,398.3	0	13	0.0	0	0
80 - 85	27.6	32	31	-80,335.3	0	4	8,923.2	0	19	0.0	0	0
85 - 90	29.2	5	5	-85,061.0	0	8	9,448.1	0	0	0.0	0	0
90 - 95	30.8	0	0	-89,786.6	0	0	9,973.0	0	0	0.0	0	0
95 - 100	32.4	0	0	-94,512.2	0	0	10,497.9	0	36	0.0	0	0
Hours Off	0.0	0	8,664	.0	0	7,021	0.0	0	0	0.0	0	8,760

SYSTEM LOAD PROFILES

By RIPCORDER ENGINEERING

**16001 2x6 Dense Wall R-55 Roof 3Pane
System Totals**

Percent Design Load	---- Cooling Load ----			---- Heating Load ----			---- Cooling Airflow ----			---- Heating Airflow----		
	Cap. (Tons)	Hours (%)	Hours	Cap. (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	1.6	97	2,920	-4,838.1	94	2,863	527.6	98	8,552	0.0	0	0
5 - 10	3.3	1	16	-9,676.1	3	79	1,055.1	0	0	0.0	0	0
10 - 15	4.9	0	0	-14,514.2	0	5	1,582.7	0	0	0.0	0	0
15 - 20	6.5	0	0	-19,352.2	1	16	2,110.2	0	0	0.0	0	0
20 - 25	8.1	0	0	-24,190.3	0	0	2,637.8	0	0	0.0	0	0
25 - 30	9.8	0	0	-29,028.3	0	0	3,165.4	0	0	0.0	0	0
30 - 35	11.4	0	0	-33,866.4	0	5	3,692.9	1	120	0.0	0	0
35 - 40	13.0	0	10	-38,704.4	0	0	4,220.5	0	16	0.0	0	0
40 - 45	14.7	0	10	-43,542.5	0	0	4,748.0	0	0	0.0	0	0
45 - 50	16.3	0	0	-48,380.5	0	10	5,275.6	0	0	0.0	0	0
50 - 55	17.9	0	4	-53,218.6	0	0	5,803.1	0	0	0.0	0	0
55 - 60	19.5	0	12	-58,056.6	1	37	6,330.7	0	0	0.0	0	0
60 - 65	21.2	0	0	-62,894.7	0	4	6,858.3	0	0	0.0	0	0
65 - 70	22.8	0	0	-67,732.7	0	8	7,385.8	0	0	0.0	0	0
70 - 75	24.4	0	0	-72,570.8	0	8	7,913.4	0	4	0.0	0	0
75 - 80	26.1	0	0	-77,408.9	0	4	8,440.9	0	8	0.0	0	0
80 - 85	27.7	1	36	-82,246.9	0	4	8,968.5	0	24	0.0	0	0
85 - 90	29.3	0	0	-87,085.0	0	8	9,496.1	0	0	0.0	0	0
90 - 95	30.9	0	0	-91,923.0	0	0	10,023.6	0	0	0.0	0	0
95 - 100	32.6	0	0	-96,761.1	0	0	10,551.2	0	36	0.0	0	0
Hours Off	0.0	0	5,752	.0	0	5,709	0.0	0	0	0.0	0	8,760

BUILDING COOL HEAT DEMAND

By RIPCORD ENGINEERING

January Hour	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
	OADB	OAWB	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)
1	28.7	26.8	-656	0.0	-541	0.0	-1,131	0.0	-541	0.0	-1,828	0.0
2	28.5	26.7	-865	0.0	-547	0.0	-1,543	0.0	-988	0.0	-1,835	0.0
3	27.9	26.4	-1,121	0.0	-560	0.0	-1,848	0.0	-1,481	0.0	-1,848	0.0
4	27.5	26.1	-1,353	0.0	-572	0.0	-1,860	0.0	-1,860	0.0	-1,860	0.0
5	27.4	25.9	-1,562	0.0	-580	0.0	-1,868	0.0	-1,868	0.0	-1,868	0.0
6	27.0	25.6	-1,628	0.0	-592	0.0	-1,880	0.0	-1,880	0.0	-1,880	0.0
7	26.8	25.5	-1,638	0.0	-602	0.0	-1,890	0.0	-1,890	0.0	-1,890	0.0
8	27.7	26.2	-1,636	0.0	-593	0.0	-1,880	0.0	-1,880	0.0	-1,880	0.0
9	29.3	27.6	-1,586	0.0	-554	0.0	-1,842	0.0	-1,842	0.0	-1,842	0.0
10	30.7	28.5	-1,548	0.0	-528	0.0	-1,815	0.0	-1,815	0.0	-1,815	0.0
11	32.7	29.7	-68,576	0.0	-502	0.0	-70,565	0.0	-1,790	0.0	-1,790	0.0
12	34.0	30.7	-62,461	0.0	-483	0.0	-60,988	0.0	-1,770	0.0	-1,770	0.0
13	35.1	31.4	-44,440	0.0	-462	0.0	-57,072	0.0	-1,749	0.0	-1,749	0.0
14	35.5	31.5	-11,773	0.0	-447	0.0	-55,852	0.0	-1,734	0.0	-1,734	0.0
15	35.5	31.5	-1,878	0.0	-840	0.0	-436	0.0	-1,724	0.0	-1,724	0.0
16	34.5	30.7	-1,520	0.0	-1,045	0.0	-441	0.0	-1,728	0.0	-1,728	0.0
17	33.2	29.9	-1,428	0.0	-1,068	0.0	-472	0.0	-1,760	0.0	-1,760	0.0
18	32.7	29.7	-1,385	0.0	-1,069	0.0	-482	0.0	-1,770	0.0	-1,770	0.0
19	32.0	29.1	-1,338	0.0	-1,067	0.0	-489	0.0	-1,776	0.0	-1,776	0.0
20	31.5	28.9	-1,308	0.0	-1,067	0.0	-494	0.0	-1,781	0.0	-1,781	0.0
21	30.9	28.3	-169	0.0	-1,073	0.0	-501	0.0	-1,789	0.0	-1,789	0.0
22	30.2	27.8	-187	0.0	-1,084	0.0	-512	0.0	-1,800	0.0	-1,800	0.0
23	29.5	27.3	-206	0.0	-1,100	0.0	-525	0.0	-1,812	0.0	-1,812	0.0
24	28.7	26.8	-224	0.0	-1,119	0.0	-537	0.0	-1,825	0.0	-1,825	0.0

February Hour	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
	OADB	OAWB	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)
1	24.5	22.2	-1,596	0.0	-633	0.0	-1,921	0.0	-1,921	0.0	-7,484	0.0
2	24.1	21.8	-1,622	0.0	-643	0.0	-1,931	0.0	-1,931	0.0	-6,875	0.0
3	23.4	21.2	-1,650	0.0	-659	0.0	-1,947	0.0	-1,947	0.0	-7,634	0.0
4	22.9	20.9	-1,678	0.0	-673	0.0	-1,960	0.0	-1,960	0.0	-7,891	0.0
5	22.8	20.8	-1,704	0.0	-683	0.0	-1,971	0.0	-1,971	0.0	-8,045	0.0
6	22.6	20.7	-1,723	0.0	-695	0.0	-1,982	0.0	-1,982	0.0	-8,472	0.0
7	22.4	20.6	-1,737	0.0	-705	0.0	-1,993	0.0	-1,993	0.0	-8,742	0.0
8	23.1	21.3	-1,676	0.0	-664	0.0	-1,951	0.0	-1,951	0.0	-7,410	0.0
9	24.6	22.4	-1,597	0.0	-617	0.0	-1,904	0.0	-1,904	0.0	-5,860	0.0
10	26.6	24.1	-1,543	0.0	-576	0.0	-1,864	0.0	-1,864	0.0	-2,151	0.0
11	28.9	25.8	-74,388	0.0	-545	0.0	-85,110	0.0	-1,832	0.0	-1,832	0.0
12	30.4	26.6	-69,835	0.0	-520	0.0	-82,341	0.0	-1,808	0.0	-1,808	0.0
13	31.6	27.5	-66,233	0.0	-497	0.0	-79,634	0.0	-1,784	0.0	-1,839	0.0
14	32.3	28.1	-66,190	0.0	-475	0.0	-74,294	0.0	-1,763	0.0	-3,757	0.0
15	32.1	28.0	-66,149	0.0	-463	0.0	-463	0.0	-1,750	0.0	-2,038	0.0
16	32.1	27.8	-64,515	0.0	-490	0.0	-490	0.0	-1,778	0.0	-5,004	0.0
17	31.0	27.0	-62,392	0.0	-525	0.0	-525	0.0	-1,812	0.0	-4,787	0.0
18	29.3	25.6	-62,423	0.0	-557	0.0	-557	0.0	-1,844	0.0	-5,886	0.0
19	28.5	25.1	-55,094	0.0	-983	0.0	-565	0.0	-6,994	0.0	-6,270	0.0
20	27.9	24.5	-54,248	0.0	-1,469	0.0	-571	0.0	-9,889	0.0	-6,549	0.0
21	27.2	24.1	-208	0.0	-1,857	0.0	-580	0.0	-8,236	0.0	-6,801	0.0
22	26.4	23.7	-231	0.0	-1,880	0.0	-831	0.0	-1,880	0.0	-7,067	0.0
23	25.8	23.2	-257	0.0	-1,893	0.0	-1,387	0.0	-6,528	0.0	-7,226	0.0
24	25.3	22.8	-283	0.0	-1,904	0.0	-1,844	0.0	-9,361	0.0	-7,485	0.0

BUILDING COOL HEAT DEMAND

By RIPCORD ENGINEERING

March Hour	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
	OADB	OAWB	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)
1	30.4	28.7	-2,453	0.0	0	0.0	-401	0.0	-401	0.0	-1,689	0.0
2	29.8	28.2	-1,443	0.0	0	0.0	-421	0.0	-421	0.0	-1,709	0.0
3	29.2	27.6	-25,439	0.0	0	0.0	-442	0.0	-442	0.0	-1,730	0.0
4	28.0	26.8	-28,199	0.0	-234	0.0	-471	0.0	-471	0.0	-1,758	0.0
5	27.3	26.2	-26,009	0.0	-495	0.0	-495	0.0	-495	0.0	-1,782	0.0
6	26.7	25.6	-26,270	0.0	-517	0.0	-517	0.0	-517	0.0	-1,805	0.0
7	27.2	26.1	-24,822	0.0	-492	0.0	-492	0.0	-492	0.0	-1,780	0.0
8	29.9	28.2	-23,791	0.0	-377	0.0	-377	0.0	-377	0.0	-1,665	0.0
9	32.5	30.0	-23,838	0.0	-288	0.0	-288	0.0	-288	0.0	-1,576	0.0
10	35.4	31.9	-31,969	0.0	-221	0.0	-609	0.0	-221	0.0	-1,508	0.0
11	37.2	33.2	-68,674	0.0	-186	0.0	-69,670	0.0	-186	0.0	-1,473	0.0
12	38.8	34.0	-68,397	0.0	-150	0.0	-66,667	0.0	-150	0.0	-1,438	0.0
13	39.4	34.5	-66,098	0.0	-121	0.0	-65,019	0.0	-720	0.0	-1,408	0.0
14	39.4	34.5	-66,098	0.0	-94	0.0	-56,014	0.0	-678	0.0	-1,382	0.0
15	39.0	34.4	-66,098	0.0	-104	0.0	-104	0.0	-666	0.0	-1,391	0.0
16	38.0	33.9	-64,546	0.0	-183	0.0	-183	0.0	-721	0.0	-1,471	0.0
17	37.0	33.3	-63,980	0.0	-239	0.0	-239	0.0	-928	0.0	-1,527	0.0
18	35.7	32.5	-63,980	0.0	-275	0.0	-275	0.0	-1,130	0.0	-1,563	0.0
19	34.6	31.5	-62,835	0.0	-290	0.0	-290	0.0	-1,274	0.0	-1,577	0.0
20	33.3	30.8	-62,257	0.0	-308	0.0	-308	0.0	-1,401	0.0	-1,595	0.0
21	32.9	30.6	0	0.0	-317	0.0	-317	0.0	-1,509	0.0	-1,605	0.0
22	32.1	30.0	0	0.0	-337	0.0	-337	0.0	-1,625	0.0	-1,625	0.0
23	31.4	29.4	0	0.0	-360	0.0	-360	0.0	-1,647	0.0	-1,647	0.0
24	30.7	28.9	0	0.0	-381	0.0	-381	0.0	-1,669	0.0	-1,669	0.0

April Hour	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
	OADB	OAWB	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)
1	37.7	34.4	-1,287	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	36.5	33.6	-1,287	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	35.9	33.3	-1,287	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	36.0	33.4	-1,287	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	35.2	32.8	-1,287	0.0	0	0.0	0	0.0	0	0.0	0	0.0
6	36.4	33.7	-1,287	0.0	0	0.0	0	0.0	0	0.0	0	0.0
7	39.5	35.5	-1,287	0.0	0	0.0	0	0.0	0	0.0	0	0.0
8	41.6	36.8	-1,052	0.0	0	0.0	0	0.0	0	0.0	-35	0.0
9	44.3	38.1	-550	0.0	0	0.0	0	0.0	0	0.0	0	0.0
10	46.5	39.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
11	47.9	39.7	-63,980	0.0	0	0.0	-55,546	0.0	0	0.0	0	0.0
12	48.8	40.2	-63,980	0.0	0	0.0	-53,937	0.0	0	0.0	0	0.0
13	48.7	40.2	-57,269	0.7	0	0.0	-47,034	0.0	0	0.0	-349	0.0
14	48.3	40.1	-57,269	1.2	0	0.0	-46,653	0.0	0	0.0	-329	0.0
15	47.7	39.6	-57,269	1.4	0	0.0	0	0.0	0	0.0	-304	0.0
16	47.1	39.3	-56,679	1.2	0	0.0	0	0.0	0	0.0	0	0.0
17	46.3	39.0	-55,546	0.8	0	0.0	0	0.0	0	0.0	0	0.0
18	44.4	37.7	-55,546	0.2	0	0.0	0	0.0	0	0.0	0	0.0
19	42.8	37.2	-48,208	0.0	0	0.0	0	0.0	0	0.0	0	0.0
20	42.0	36.9	-46,653	0.0	0	0.0	0	0.0	0	0.0	0	0.0
21	41.3	36.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
22	40.2	36.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
23	39.5	35.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	39.0	35.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

BUILDING COOL HEAT DEMAND

By RIPCORD ENGINEERING

May Hour	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
	OADB	OAWB	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)
1	49.6	45.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	48.8	45.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	48.0	44.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	47.0	44.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	47.0	44.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
6	48.6	45.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
7	51.7	46.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
8	54.2	48.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
9	57.0	49.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
10	59.0	49.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
11	61.1	50.9	-55,546	4.5	0	0.0	-15,928	2.1	0	0.0	0	0.0
12	62.0	51.0	-55,546	5.4	0	0.0	-15,928	2.2	0	0.0	0	0.0
13	63.0	51.6	-55,546	6.0	0	0.0	-15,763	2.6	0	0.0	0	0.0
14	63.5	51.8	-46,653	6.5	0	0.0	-15,423	2.8	0	0.0	0	0.0
15	63.5	51.9	-46,157	6.8	0	0.0	0	0.0	0	0.0	0	0.0
16	62.9	51.8	-42,258	7.2	0	0.0	0	0.0	0	0.0	0	0.0
17	61.3	51.0	-17,233	7.3	0	0.0	0	0.0	0	0.0	0	0.0
18	59.6	50.5	-17,233	6.6	0	0.0	0	0.0	0	0.0	0	0.0
19	57.1	49.5	-17,233	5.5	0	0.0	0	0.0	0	0.0	0	0.0
20	55.0	48.7	-17,056	4.5	0	0.0	0	0.0	0	0.0	0	0.0
21	53.9	48.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
22	52.7	47.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
23	51.7	46.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	50.6	46.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

June Hour	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
	OADB	OAWB	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)
1	59.0	56.0	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
2	58.2	55.4	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
3	57.6	55.1	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
4	57.2	54.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	57.9	55.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
6	60.3	56.2	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
7	62.9	57.7	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
8	66.5	59.4	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
9	69.4	60.4	0	0.1	0	0.1	0	0.1	0	0.1	0	0.1
10	71.7	61.5	0	0.1	0	0.1	0	0.1	0	0.1	0	0.1
11	73.0	61.7	-14,878	11.0	0	0.1	0	18.8	0	0.1	0	0.1
12	74.6	61.9	-1,950	11.5	0	0.1	0	18.3	0	0.1	0	0.1
13	75.2	61.8	-1,930	11.8	0	0.1	0	18.0	0	0.1	0	0.1
14	75.0	61.8	-802	12.4	0	0.1	0	17.7	0	0.1	0	0.1
15	75.2	61.7	-572	12.9	0	0.1	0	0.1	0	0.1	0	0.1
16	74.2	61.3	-539	13.6	0	0.1	0	0.1	0	0.1	0	0.1
17	73.3	61.0	-516	13.9	0	0.1	0	0.1	0	0.1	0	0.1
18	70.9	60.4	-516	13.7	0	0.0	0	0.0	0	0.0	0	0.0
19	68.1	59.6	-516	13.9	0	0.0	0	0.0	0	0.0	0	0.0
20	65.7	58.9	-516	25.0	0	0.0	0	0.0	0	0.0	0	0.0
21	64.3	58.4	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
22	62.8	57.8	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
23	61.1	57.0	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
24	60.1	56.5	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0

BUILDING COOL HEAT DEMAND

By RIPCORD ENGINEERING

July Hour	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
	OADB	OAWB	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)
1	64.9	61.0	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
2	64.4	60.6	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
3	63.6	60.2	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
4	62.7	59.9	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
5	62.8	60.1	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
6	65.1	61.4	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
7	67.8	62.6	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
8	71.1	63.8	0	0.1	0	0.1	0	0.1	0	0.1	0	0.1
9	73.7	64.4	0	0.1	0	0.1	0	0.1	0	0.1	0	0.1
10	76.1	65.1	0	0.1	0	0.1	0	0.1	0	0.1	0	0.1
11	77.5	65.4	0	28.1	0	0.1	0	27.7	0	0.1	0	0.1
12	78.9	65.7	0	28.0	0	0.1	0	27.4	0	0.1	0	0.1
13	79.6	65.8	0	27.6	0	0.1	0	27.0	0	0.1	0	0.1
14	79.7	65.8	0	27.7	0	0.1	0	26.9	0	0.1	0	0.1
15	79.5	65.6	0	28.0	0	0.1	0	0.1	0	0.1	0	0.1
16	78.6	65.4	0	28.3	0	0.1	0	0.1	0	0.1	0	0.1
17	77.5	65.1	0	28.4	0	0.1	0	0.1	0	0.1	0	0.1
18	75.9	64.4	0	27.6	0	0.1	0	0.1	0	0.1	0	0.1
19	73.0	63.9	0	27.2	0	0.1	0	0.1	0	0.1	0	0.1
20	70.4	62.9	0	27.2	0	0.1	0	0.1	0	0.1	0	0.1
21	69.0	62.5	0	0.1	0	0.1	0	0.1	0	0.1	0	0.1
22	67.9	62.5	0	0.1	0	0.1	0	0.1	0	0.1	0	0.1
23	66.4	61.9	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
24	66.1	61.7	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0

August Hour	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
	OADB	OAWB	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)
1	63.9	61.0	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
2	63.2	60.7	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
3	63.0	60.5	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
4	62.5	60.1	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
5	62.1	59.6	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
6	63.5	60.5	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
7	65.5	61.1	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
8	68.6	62.6	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
9	71.0	63.5	0	0.1	0	0.1	0	0.1	0	0.1	0	0.1
10	73.3	64.4	0	0.1	0	0.1	0	0.1	0	0.1	0	0.1
11	74.8	64.6	0	30.9	0	0.1	0	26.7	0	0.1	0	0.1
12	75.4	64.5	0	30.9	0	0.1	0	26.6	0	0.1	0	0.1
13	76.3	64.7	0	31.1	0	0.1	0	26.8	0	0.1	0	0.1
14	76.4	64.8	0	31.8	0	0.1	0	26.9	0	0.1	0	0.1
15	76.3	64.9	0	32.0	0	0.1	0	0.1	0	0.1	0	0.1
16	75.7	64.8	0	32.1	0	0.1	0	0.1	0	0.1	0	0.1
17	73.7	64.0	0	31.9	0	0.1	0	0.1	0	0.1	0	0.1
18	71.7	63.5	0	31.4	0	0.1	0	0.1	0	0.1	0	0.1
19	68.7	62.7	0	31.1	0	0.0	0	0.0	0	0.0	0	0.0
20	67.4	62.3	0	30.8	0	0.0	0	0.0	0	0.0	0	0.0
21	66.4	61.7	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
22	65.9	61.7	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
23	65.0	61.1	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
24	64.3	61.3	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0

BUILDING COOL HEAT DEMAND

By RIPCORD ENGINEERING

September	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
	Hour	OADB	OAWB	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)
1	55.5	53.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	55.1	53.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	54.6	52.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	54.2	52.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	53.8	52.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
6	53.9	52.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
7	56.1	54.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
8	59.2	55.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
9	62.4	57.1	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
10	64.8	57.9	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
11	66.6	58.6	0	28.1	0	0.0	0	12.4	0	0.0	0	0.0
12	67.6	58.9	0	29.5	0	0.0	0	12.7	0	0.0	0	0.0
13	68.8	59.2	0	30.7	0	0.0	0	13.6	0	0.0	0	0.0
14	68.6	59.1	0	28.9	0	0.0	0	13.7	0	0.0	0	0.0
15	67.9	58.8	0	28.9	0	0.0	0	0.0	0	0.0	0	0.0
16	67.1	58.7	0	28.4	0	0.0	0	0.0	0	0.0	0	0.0
17	65.0	58.2	0	30.5	0	0.0	0	0.0	0	0.0	0	0.0
18	61.9	56.9	0	29.2	0	0.0	0	0.0	0	0.0	0	0.0
19	60.3	56.2	0	27.8	0	0.0	0	0.0	0	0.0	0	0.0
20	59.7	55.7	0	26.2	0	0.0	0	0.0	0	0.0	0	0.0
21	58.3	55.1	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
22	57.6	54.8	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
23	56.5	54.1	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
24	55.7	53.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
October	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
Hour	OADB	OAWB	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)
1	45.0	43.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	44.4	42.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	43.7	42.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	43.4	41.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	43.5	41.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
6	43.0	41.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
7	44.5	42.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
8	47.4	43.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
9	50.1	45.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
10	52.7	46.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
11	54.0	47.0	0	4.0	0	0.0	0	0.0	0	0.0	0	0.0
12	55.3	47.7	0	6.4	0	0.0	0	0.0	0	0.0	0	0.0
13	55.7	48.1	0	8.2	0	0.0	0	0.2	0	0.0	0	0.0
14	55.9	48.1	0	8.2	0	0.0	0	0.3	0	0.0	0	0.0
15	55.6	47.9	0	9.1	0	0.0	0	0.0	0	0.0	0	0.0
16	54.4	47.4	0	9.9	0	0.0	0	0.0	0	0.0	0	0.0
17	51.8	46.4	0	9.2	0	0.0	0	0.0	0	0.0	0	0.0
18	49.9	45.6	0	7.3	0	0.0	0	0.0	0	0.0	0	0.0
19	48.9	45.2	0	5.3	0	0.0	0	0.0	0	0.0	0	0.0
20	47.8	44.5	0	2.9	0	0.0	0	0.0	0	0.0	0	0.0
21	47.5	44.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
22	46.5	43.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
23	45.9	43.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	45.4	42.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

BUILDING COOL HEAT DEMAND

By RIPCORD ENGINEERING

November	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
	Hour	OADB	OAWB	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)
1	35.5	33.6	0	0.0	0	0.0	0	0.0	0	0.0	-695	0.0
2	35.5	33.4	0	0.0	0	0.0	0	0.0	0	0.0	-711	0.0
3	35.6	33.6	0	0.0	0	0.0	0	0.0	0	0.0	-726	0.0
4	35.1	33.3	0	0.0	0	0.0	0	0.0	0	0.0	-750	0.0
5	34.9	33.1	0	0.0	0	0.0	0	0.0	0	0.0	-771	0.0
6	34.5	32.8	0	0.0	0	0.0	0	0.0	0	0.0	-794	0.0
7	34.5	32.7	0	0.0	0	0.0	0	0.0	0	0.0	-812	0.0
8	35.8	33.4	0	0.0	0	0.0	0	0.0	0	0.0	-789	0.0
9	37.7	34.5	0	0.0	0	0.0	0	0.0	0	0.0	-760	0.0
10	40.3	36.1	0	0.0	0	0.0	0	0.0	0	0.0	-732	0.0
11	42.1	37.1	0	0.0	0	0.0	-6,127	0.0	0	0.0	-714	0.0
12	42.8	37.5	0	0.0	0	0.0	-5,252	0.0	0	0.0	-704	0.0
13	43.6	37.9	0	0.0	0	0.0	-2,416	0.0	0	0.0	-686	0.0
14	43.6	37.9	-476	0.0	0	0.0	-2,550	0.0	0	0.0	-671	0.0
15	43.0	37.7	-458	0.0	0	0.0	0	0.0	0	0.0	-660	0.0
16	42.0	37.2	-439	0.0	0	0.0	0	0.0	0	0.0	-675	0.0
17	40.1	36.4	-419	0.0	0	0.0	0	0.0	-343	0.0	-698	0.0
18	39.3	36.0	-402	0.0	0	0.0	0	0.0	-383	0.0	-699	0.0
19	38.9	35.7	-387	0.0	0	0.0	0	0.0	-620	0.0	-695	0.0
20	38.2	35.4	-377	0.0	0	0.0	0	0.0	-624	0.0	-698	0.0
21	37.6	35.1	0	0.0	0	0.0	0	0.0	-632	0.0	-706	0.0
22	37.1	34.7	0	0.0	0	0.0	0	0.0	-644	0.0	-718	0.0
23	36.6	34.4	0	0.0	0	0.0	0	0.0	-658	0.0	-731	0.0
24	35.6	33.4	0	0.0	0	0.0	0	0.0	-681	0.0	-754	0.0

December	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
	Hour	OADB	OAWB	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)
1	31.2	29.1	-204	0.0	-456	0.0	-918	0.0	-926	0.0	-1,647	0.0
2	30.6	28.6	-532	0.0	-469	0.0	-943	0.0	-951	0.0	-1,757	0.0
3	30.2	28.1	-604	0.0	-483	0.0	-968	0.0	-976	0.0	-1,770	0.0
4	29.9	27.8	-644	0.0	-494	0.0	-992	0.0	-1,000	0.0	-1,782	0.0
5	29.7	27.6	-682	0.0	-506	0.0	-1,015	0.0	-1,023	0.0	-1,793	0.0
6	29.3	27.3	-714	0.0	-519	0.0	-1,040	0.0	-1,048	0.0	-1,806	0.0
7	28.7	26.8	-740	0.0	-535	0.0	-1,068	0.0	-1,076	0.0	-1,823	0.0
8	29.6	27.6	-754	0.0	-532	0.0	-1,076	0.0	-1,083	0.0	-1,820	0.0
9	32.1	29.5	-726	0.0	-482	0.0	-1,036	0.0	-1,043	0.0	-1,769	0.0
10	34.6	31.3	-707	0.0	-444	0.0	-1,008	0.0	-1,015	0.0	-1,731	0.0
11	36.4	32.4	-62,232	0.0	-903	0.0	-54,789	0.0	-1,000	0.0	-1,707	0.0
12	38.2	33.4	-59,361	0.0	-882	0.0	-53,530	0.0	-978	0.0	-1,679	0.0
13	38.9	33.7	-54,824	0.0	-868	0.0	-53,513	0.0	-964	0.0	-1,662	0.0
14	39.1	33.7	-47,538	0.0	-851	0.0	-31,402	0.0	-946	0.0	-1,647	0.0
15	38.7	33.6	-31,108	0.0	-834	0.0	-350	0.0	-929	0.0	-1,637	0.0
16	37.4	33.0	-31,090	0.0	-826	0.0	-351	0.0	-920	0.0	-1,639	0.0
17	35.4	31.9	-30,720	0.0	-853	0.0	-390	0.0	-947	0.0	-1,678	0.0
18	34.5	31.4	-11,260	0.0	-854	0.0	-728	0.0	-948	0.0	-1,690	0.0
19	34.1	31.1	-11,039	0.0	-846	0.0	-792	0.0	-940	0.0	-1,691	0.0
20	33.0	30.3	-10,783	0.0	-853	0.0	-830	0.0	-947	0.0	-1,704	0.0
21	32.5	30.1	-128	0.0	-859	0.0	-867	0.0	-952	0.0	-1,711	0.0
22	31.7	29.5	-148	0.0	-875	0.0	-883	0.0	-967	0.0	-1,725	0.0
23	31.4	29.1	-168	0.0	-888	0.0	-896	0.0	-981	0.0	-1,733	0.0
24	30.9	28.7	-185	0.0	-907	0.0	-914	0.0	-1,312	0.0	-1,742	0.0

SYSTEM SUMMARY
DESIGN COOLING CAPACITIES
 By RIPCORD ENGINEERING

Alternative 1

Building Airside Systems and Plant Capacities

Plant	System	Peak Plant Loads							Block Plant Loads									
		Main Coil ton	Aux Coil ton	Opt Vent Coil ton	Misc Load ton	Stg 1	Stg 2	Base Utility ton	Peak Total ton	Time Of Peak mo/hr	Main Coil ton	Aux Coil ton	Opt Vent Coil ton	Misc Load ton	Stg 1	Stg 2	Base Utility ton	Block Total ton
						Desic Cond ton	Desic Cond ton								Desic Cond ton	Desic Cond ton		
Cooling plant - 003	Server Room	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.2	7/11	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.2
Cooling plant - 008	System - 008	32.4	0.0	0.0	0.0	0.0	0.0	0.0	32.4	8/16	31.9	0.0	0.0	0.0	0.0	0.0	0.0	31.9
Building totals		32.5	0.0	0.0	0.0	0.0	0.0	0.0	32.5		32.1	0.0	0.0	0.0	0.0	0.0	0.0	32.1

Building peak load is 32.6 tons.

Building maximum block load of 32.1 tons occurs in August at hour 16 based on system simulation.

SYSTEM SUMMARY
DESIGN HEATING CAPACITIES
 By RIPCORN ENGINEERING

Alternative 1

System Coil Capacities

System Description	System Type	Main	Aux	Preheat	Reheat	Humid.	Optional	Stg 1	Stg 2	Stg 1	Stg 2	Heating
		System	System					Desic	Desic	Frost	Frost	
		Btu/h	Btu/h	Btu/h	Btu/h	Btu/h	Btu/h	Regen	Regen	Prevention	Prevention	Totals
Server Room	Computer Room Unit	-2,249	0	0	-1,197	0	0	0	0	0	0	-2,249
System - 008	Variable Volume Reheat (30% Min Flow Default)	-68,675	0	-25,837	-55,623	0	0	0	0	0	0	-94,512
Totals		-70,924	0	-25,837	-56,820	0	0	0	0	0	0	-96,761

Building Plant Capacities

Plant	System	Peak Loads											Absorption	
		Main	Preheat	Reheat	Humid.	Aux	Opt Vent	Misc	Stg 1	Stg 2	Stg 1	Stg 2		Base
		Coil	Coil	Coil	Coil	Coil	Coil	Load	Desic.	Desic.	Frost	Frost		
MBh	MBh	MBh	MBh	MBh	MBh	MBh	MBh	MBh	MBh	MBh	MBh	MBh	MBh	
Heating plant - 002		0	26	0	0	0	0	0	0	0	0	0	23	0
	System - 008	0	26	0	0	0	0	0	0	0	0	0	0	0
Heating plant - 004		71	0	0	0	0	0	0	0	0	0	0	0	0
	Server Room	2	0	0	0	0	0	0	0	0	0	0	0	0
	System - 008	69	0	0	0	0	0	0	0	0	0	0	0	0

Building peak load is 119.8 MBh.